

COAHOMA  
 L49  
 9-3-79

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

BUTANE GAS COMPANY  
 OF GREENWOOD

Coahoma  
 county well located

9-3-79  
 date well completed

LANDOWNER:	description of formations encountered	from	to
John H. Flowers			
CLARKSDALE (mailing address)	SAND	18	70
WELL LOCATION: sec. 5 T. 26 N. R. 4 E 4 miles SW of CLARKSDALE (distance) (direction) (nearest town)	GRAVEL	70	180
WELL PURPOSE: Home (home, irrigation, municipal, industrial)	SANDY CLAY	180	285
WELL COMPLETION DATA:	CLAY	285	330
(1) diameter (inches) 4 X 2	SAND	330	440
(2) total depth (feet) 1075	SAND + Siltstone	440	470
(3) static water level (feet) 12 below top of ground.	SAND	470	520
(4) casing (material) Steel, (depth) 1055, (size) 4 X 2 If telescope see back.	Siltstone	520	670
(5) screen (length) 20, (depth to top) 1055, (size) 2", (material) STAINLESS	SANDY Siltstone + Rock	670	700
(6) pump (HP) 1, (yield gpm) 20, (type power) Elec	HARD Siltstone	700	765
(7) electric log (yes or no) N/S	FINE SAND - Siltstone - Rock	765	820
(organization running log)	Siltstone	820	1025
(8) how well bottom plugged Back Pressure Valve	SAND	1025	1078
DRILLERS REMARKS:	Siltstone + FINE SAND	1078	1120

CODED

Miss. Board of Water Comm.

SEP - 5 1979

RECEIVED