

# STATE WELL REPORT

## Part I

### Driller's Log

Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 2309  
 Jackson, MS 39225-2309  
 (601)961-5210  
 (601)360-0535 (fax)

### For Office Use Only:

Well #: L143  
 Aquifer: \_\_\_\_\_  
 E-Log #: \_\_\_\_\_

County: Coahoma  
 Permit #: GW-49057 ✓  
 Driller: Clarence McMurry  
 Date drilling completed: 5-7-16

*State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.*

|  |                    |  |   |
|--|--------------------|--|---|
| <b>Well Owner Information</b><br>(Landowner if borehole is not for a water well) |                    | <b>Well or Borehole Location</b>   |   |
| Owner Name: <u>JWBMS, LLC</u>  |                    | Latitude: <u>34°09'17.40"</u> Longitude: <u>90°33'32.59"</u>   |   |
| Mailing Address: <u>4424 Caroline Hwy</u>  |                    | Method of Lat./Long (check one): Conventional Survey _____<br>USGS quad _____ Hand-held GPS _____ Survey-grade GPS _____ |   |
| <u>Denmark</u><br>City   | <u>SC</u><br>State | <u>29042</u><br>Zip Code   | <u>SW 1/4 NE 20th, Sec 12 T.26N R.04W</u><br><u>3.13</u> Miles <u>South</u> of <u>Clarksdale</u><br>(Distance) (Direction) (Nearest Town) |
| Telephone No. <u>(662) 332-4458</u>  |                    |  |   |

**Well / Borehole Data**

Date drilling started: 5-7-16 Date drilling completed: 5-7-16 Hole depth: 125' Hole diameter: 26"

Location of the source of any surface water used for drilling: Handed from nearby well

Method of dosing and volume of Chlorine used in drilling and development: \_\_\_\_\_

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: \_\_\_\_\_

Name of organization running log(s): \_\_\_\_\_

Purpose of borehole (circle one): Water Well Geotechnical/Geological Investigation Ground Source Heat Pump  
 Seismic Survey Other (describe): \_\_\_\_\_

*If drilling is not related to water well construction, skip the remainder of this block*

Purpose of Well (circle all applicable): Home Industrial Public Supply Recreation Fish Culture

Other (describe): \_\_\_\_\_

If a flowing well, method of flow regulation: Valve \_\_\_\_\_ Other (describe) \_\_\_\_\_

Static Water Level: 37 feet (above or below land surface) (circle one) Date measured: 5-7-16

Method of measurement (circle one): Steel tape Electric tape Air line Other (describe): \_\_\_\_\_

Well depth: 125' Well grouted to a depth of: \_\_\_\_\_ feet Type of grout (circle one): Neat Cement Bentonite Mix

Casing length: 75 feet Casing diameter: 16 inches Type of casing: PVC

Screen length: 50 feet Screen diameter: 16 inches Type of screen: PVC

Screen slot size: .050 inches Setting depth: From 75 feet to 125 feet

Type of completion (circle all applicable): Gravel packed Underreamed Open hole Natural Development

Other (describe): \_\_\_\_\_

Top of lap pipe or reduction in casing: N/A feet

*If telescoped or more than one screen, describe on next page*



### STATE WELL REPORT

County: Cochran  
 Permit #: GW-49057  
 Driller: Scott Hood  
 Date completed: 5-7-16  
*Copy information from block on Part 1*

Part 2  
**Pump Installer's Completion Report**  
 Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 2309  
 Jackson, MS 39225-2309  
 (601)961-5210  
 (601) 360-0535 (fax)

**For Office Use Only:**  
 Well #: L143  
 Aquifer: \_\_\_\_\_

*This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.*

| Well Owner Information                    |   |  | Well Location  |  |  |
|---|---|--|--|--|--|
| Owner Name: <u>JWOBMS, LLC</u>            | Latitude: <u>34° 07' 17.40"</u>                           |  | Longitude: <u>90° 33' 32.59"</u>                             |  |  |
| Mailing Address: <u>4424 Carolina Hwy</u> | Method of Lat/Long (check one): Conventional Survey _____ |  | USGS quad _____, Hand-held GPS _____, Survey-grade GPS _____ |  |  |
| <u>Denmark</u> <u>SC</u> <u>29042</u>     | City State Zip Code                                       |  | <u>SW 1/4 and NE 1/4, Sec 22 T. 26N R. 04W</u>               |  |  |
| Telephone No. <u>(662) 332-4458</u>       | <u>SW</u> Miles <u>south</u> of <u>Clarksdale</u>         |  | (Distance) (Direction) (Nearest Town)                        |  |  |

**Pump Type (circle one)**  
 Submersible  Air Lift Centrifugal Flowing Well Jet Piston Rotary Other (describe): \_\_\_\_\_  
 Date Pump Installed: 5-7-16 Rated Pump Capacity: \_\_\_\_\_ Gallons Per Minute  
 Is This Pump (circle one):  New Repaired Replacement

**Power Type (circle one)**  
 Electric Diesel Gasoline Natural Gas Tractor PTO Windmill Other (describe): Gear Drive  
 Horse Power Rating of Motor: 60 Setting Depth: 80 feet Number of Stages: 1

**Pump Test Data for Non Flowing Well**  
 Date Well Tested: NOT TESTED Duration of Pump Test (minimum 4 hours): N/A hours  
 Static Water Level (A): 37 Feet Below Land Surface Pumping Water Level (B): N/A Feet Below Land Surface  
 Drawdown [(B) - (A)]: N/A Feet Below Land Surface Test Pumping Rate: N/A Gallons Per Minute  
 Method of measurement (circle one): Steel tape  Electric tape Air line Other (describe): \_\_\_\_\_

**Pump Test Data for Flowing Well**  
 Measured shut in head: \_\_\_\_\_ feet.  
 Well yielded \_\_\_\_\_ GPM with a drawdown of \_\_\_\_\_ feet after \_\_\_\_\_ hours of pumping

**Meter Installation**  
 Meter Manufacturer: \_\_\_\_\_ Meter Serial Number: \_\_\_\_\_  
 Meter Model Number/Name: \_\_\_\_\_ Type of Meter: \_\_\_\_\_  
 Totalizer Register Unit and Multiplier Factor (AF x .001, gal x 1000, etc): \_\_\_\_\_  
 Installation Date: \_\_\_\_\_ Meter installed by: \_\_\_\_\_  
 Is This Meter (circle one): New Repaired Replacement  
*Important: By submitting the above information you are certifying that this meter was installed to manufacturer standards. For agricultural wells, a list of approved meters is on the MDEQ website.*

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.  
Clayton Miller D-703 5-26-16 Clayton Miller  
 Print Name of Pump Installer and License No. (if applicable) Date Signature of Pump Installer

L143

**STATE OF MISSISSIPPI**  
**Department of Environmental Quality**  
**Office of Land and Water Resources**  
**P. O. Box 2309**  
**Jackson, Mississippi 39225**

**PERMIT**

**TO DIVERT OR WITHDRAW FOR BENEFICIAL USE THE PUBLIC WATERS**

This permit is issued to the landowner named below in accordance with the provisions of the Mississippi Water Laws, Mississippi Code Sections 51-3-1, et seq. (1972, as amended), and the regulations and standards as promulgated thereunder. Whether or not specifically named in this permit or in the applications for this permit, anyone using water from the diversion/withdrawal point described below shall do so in compliance with the provisions of this permit. Neither this permit, nor any authority conferred hereby, may be sold, conveyed, encumbered, assigned, or otherwise aliened, for any period of time or under any conditions whatsoever. This permit may not be modified, transferred or revoked without prior action by the Permit Board. Any attempts to modify, transfer or revoke this permit, or to take any other action on this permit, shall be invalid and unenforceable and may result in immediate revocation or suspension of this permit. The holder of this permit shall at all times be responsible for adherence to the terms and conditions of this permit. No agreement between the permit holder and any other party shall affect the obligations and liabilities of the permit holder. Water use under this permit is allowed only when the streamflow, lake level elevation, or static groundwater level (whichever, if any, is applicable) is above the established minimum, pursuant to Mississippi Code Section 51-3-7. Authorization is hereby granted to divert/withdraw water for the beneficial use designated herein, and for no other purpose, subject to the following terms, conditions, and limitations:

**Permit Number: MS-GW-49057**

**Landowner Name: JWBMS LLC**

**Landowner Address: 4424 CAROLINA HIGHWAY**  
**DENMARK SC 29042**

**Source Of Water: MISSISSIPPI RIVER VALLEY ALLUVIAL AQUIFER**

**Beneficial Use: IRRIGATION**

**Diversion/Withdrawal Location: SW 1/4 of the NE 1/4 Section: 01 Township: 26N Range: 04W**

**County: COAHOMA**

**Quad: CLARKSDALE**

**Maximum Volume: 191 Acre-Foot/Year equivalent to .1705 Million Gallons/Day**

**Maximum Rate: 2500 Gallons/Minute**

**Applicant Name: JWBMS LLC**

**Applicant Address: 4424 CAROLINA HIGHWAY**  
**DENMARK SC 29042**

**Date Permit Issued: 10/08/2015**

**Date Permit Expires: 10/08/2020**

**Date Permit Modified:**

**Date Permit Re-Issued:**

This permit shall be deemed null and void if construction has not begun within one (1) year of permit issue date

**SPECIAL TERMS AND CONDITIONS:**

**SPECIAL TERMS AND CONDITIONS 2: SEE ATTACHMENT 1, WHICH IS HEREBY DECLARED TO BE PART OF THIS PERMIT.**



**Gary C. Rikard, Executive Director**  
**Mississippi Department of Environmental Quality**