MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Coahoma
WELL NUMBER	N 2005
CODED	
DATE WELL COMPLETED	8-19-93
PERMIT NUMBER	
NAME OF DRILLING FIRM	IRRIGATION EQUIPMENT. 601/887-2555 INDIANOLA, MS

NAME & MAILING ADDRESS OF LANDOWNER
Howard Holdeman Farms
20 Jones Road
Clarksdale, MS 38614

WELL LOCATION:	SEC	TOWNSHIP	RANGE
SE/SE	19	25 (N) S	4 (E) W

DISTANCE	DIRECTION	NEAREST TOWN
3 Miles	West of	Rowdaway

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Irrigation

PUMP DATA

PUMP TYPE (Circle One): (Submersible), Turbine, Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One): (Electric), Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 10

Pump Capacity (GPM)	No. of Stages	Setting Depth
550	1	60 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
105	10	65

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	105	18

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed), Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF _____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks
Circle S

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
10	40	.030

Screen Type	Depth to Bottom - Feet
PVC	105

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Soil	0	2
Clay	2	25
Clay + Sand	25	45
medium Sand	45	55
Coarse Sand	55	95
Sand + Gravel	95	105

FORMATIONS (Continued)	FROM	TO

RECEIVED
OCT 19 1993
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK