COPIAH MISSISSIPPI BOARD OF WATER COMMISSIONERS 7165

A1

5-18-62

WATER WELL DRILLERS LOG

A1

CODED

Date: May 18, 1962, Driller: Burney Water Well Serv County Copiah
(Name)

(1) Owner of Land: Branch Health Center Project. No. 737
(Name)

Carpenter, Miss.
(Address)

(2) Location: SE ¼, ____ ¼, Sec. 11 T 12 R 5,

____ miles ____, of ____,
(distance) (direction) (Nearest Town)

(3) Topography: Level
(Hilly) (Flat) (Level)

(4) Purpose of Well: Municipal
(Domestic Irrigation Municipal, Industrial, Other)

Information upon completion of well:

(1) Diameter 4 inches.

(2) Total Depth 143 feet.

(3) Water Level 18 feet below top of ground.

(4) Cased to 123', Size 2",

(5) Screen: Size 2", Length 15'.

(6) Were any formations sealed against pollution?

x yes, ____ no.

If YES depth of formation ____,

Why ____

Drillers Remarks: Cement grout poured in top 20' of well. Formation packer installed at 38' below top water strata. H.T.H. used to kill all bacteria.

Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thickness Feet	Depth Feet
Topsoil & grey formation	23	2
Sand strata	15	3
Grey clay	8	4
Blue clay	62	10
Water Strata	22	13
Layers sand & clay	10	14
Blue shale	3	14

Mail this copy to Board of Water Commission