

P. O. Box 10631  
Jackson, MS 39289-0631  
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED <u>Copiah</u>		PERMIT NUMBER
WELL NUMBER <u>K-47</u>	CODED	NAME OF DRILLING FIRM <u>Green Water Well &amp; Supply, Inc.</u>
DATE WELL COMPLETED <u>4/17/03</u>		

NAME & MAILING ADDRESS OF LANDOWNER  
Grady Harvey / M.L. Wilson  
1070 Pitts Ln., Crystal Springs

Latitude:  
Longitude:

WELL LOCATION. SEC 17 TOWNSHIP N 1 S 1 E RANGE 1 W

DISTANCE 5 Miles DIRECTION SW of Crystal Springs NEAREST TOWN

OTHER LANDMARK

WELL PURPOSE  Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):  
 Submersible, Turbine, Jet, Flowing Well,  
Other (Describe)

POWER TYPE (Circle One):  
 Electric, Tractor, Diesel, Gasoline, Butane,  
Other (Describe) H/P = 25

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>gravel</u>	<u>0</u>	<u>20</u>
<u>gravel streaky</u>	<u>20</u>	<u>40</u>
<u>gravel</u>	<u>40</u>	<u>60</u>
<u>sand</u>	<u>60</u>	<u>190</u>
<u>sand rock</u>		<u>190</u>

RECEIVED  
MAY 13 2003  
BY: OLWR

Top of Lap Pipe or Reduction in Casing  
FEET  IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

WELL DATA

Well Depth <u>184'</u>	Casing Diameter (In.) <u>4</u>	Casing Length (Ft.) <u>174'</u>
Type of Casing <u>PVC</u>	Hole Depth <u>190'</u>	Depth to Static Water Level <u>90'</u>

TYPE OF COMPLETION: (Circle One or More):  
 Gravel Packed, Underreamed, Telescoped,  
Natural Development, Open Hole, Other  
(Describe)

WELL GROUTED TO A DEPTH OF 10 FEET  
Type Grout (circle one): Cement, Bentonite, or  Mix

SCREEN DATA

Diameter - Inches <u>4</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>.010</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>184</u>	

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Brian McClendon 664  
Signature of Licensed Driller and License No.

4/17/03  
Date

Additional Information Required On Back