6/28

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources
P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Copiah
WELL NUMBER: K-2022 | CODED:
DATE WELL COMPLETED: 7-10-99

NAME OF DRILLING FIRM: Crehm Water Well & Supply
ADDRESS: 1318 Pricedale Dr. SE
CITY: Bogue Chitto, MS 39629

NAME & MAILING ADDRESS OF LANDOWNER:
Louise Page
1178 Page Rd
Crystal Springs

WELL LOCATION: SEC. 30 TOWNSHIP 1 N/S RANGE 1 E/W
DISTANCE: 2 Miles DIRECTION: NE NEAREST TOWN: of Hazlehurst
OTHER LANDMARK:
WELL PURPOSE (Home, Irrigation, Municipal, Industrial, Fish Pond, etc): Home

PUMP DATA
PUMP TYPE (Circle One): (Submersible) Turbine Jet Flowing Well
Other (Describe):
POWER TYPE (Circle One): (Electric) Tractor Diesel Gasoline Butane
Other (Describe): 1 H/P

Pump Capacity (GPM)	No. of Stages	Setting Depth
16	10	110 FT.

PUMP TEST:
Well yielded 16 GPM with
a drawdown of 0 ft.
after 1 hours of pumping

WELL DATA

Well Depth	Casing Diameter (in.)	Casing Length (ft.)
190'	4"	180'

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	196'	38'

TYPE OF COMPLETION: (Circle One or More):
(Gravel Packed) Underreamed Telescoped
Natural Development Open Hole Other
(Describe):

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter (Inches)	Length (Feet)	Slot Size (Inches)
4"	10'	.010

Screen Type	Depth to Bottom (Feet)
PVC	190

LOG DATA
TYPE OF LOG RUN (Circle One): (No Log Run)
Electric Gamma Ray Density Sonic Neutron
Other (Describe):
Name of Organization Running Log:

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. Sur.	Date	Analysis	Aquifer Test

Driller's Remarks:
Total Depth Reduction FEET
If TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

RECEIVED
JUN 01 2000
Dept. of Environmental Quality
Office of Land & Water Resources

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Red Clay	0	12
Sand	12	38
Yellow Clay	38	48
Blue Clay	48	168
Sand	168	190

FORMATIONS (Continued)	FROM	TO

If MORE SPACE IS NEEDED, USE BACK