

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Copiah		PERMIT NUMBER: 518
WELL NUMBER: 319515	CODED	NAME OF DRILLING FIRM: Easley Waterwell
DATE WELL COMPLETED: 7-29-00		LOCATION: B'hamen, MS 39601

NAME & MAILING ADDRESS OF LANDOWNER:
Mr. Vaedaman
2106 Vaedaman Rd
Hermanville MS

WELL LOCATION: SEC **1** TOWNSHIP **10 N** RANGE **5 W**

DISTANCE _____ MILES _____ OF _____ NEAREST TOWN

OTHER LANDMARK _____

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Chicken House

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P _____

Pump Capacity (GPM) _____ No. of Stages _____ Setting Depth _____ FT.

PUMP TEST

Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth: 260'	Casing Diameter (In.): 4"	Casing Length (Ft.): 240
Type of Casing: PVC	Hole Depth	Depth to Static Water Level

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF **10** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log _____

SCREEN DATA

Diameter - Inches: 4"	Length - Feet	Slot Size - Inches: 8-10
Screen Type: PVC	Depth to Bottom - Feet	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks _____

Top of Lap Pipe or Reduction in Casing _____ FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Clay	0	10			
Sand	10	95			
Clay	95	200			
Sand	200	260			

REC'D JUN 13 2001

IF MORE SPACE IS NEEDED, USE BACK