

Plugged and Abandoned by Donald Smith Co. 11/27/07

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Copiah	
WELL NUMBER 12	CODED
PERMIT NUMBER MS-GW-15723	
NAME OF DRILLING FIRM Layne-Central	
DATE WELL COMPLETED 8/21/2001	
JACKSON, MS	

CTHL quotes

NAME & ADDRESS OF LANDOWNER City of Hazlehurst			
PO Box 367			
Hazlehurst, MS 39083			
LATITUDE			
LONGITUDE			
WELL LOCATION NW 1/4 NW 1/4	SEC S 10	TOWNSHIP 10N	RANGE 8E
DISTANCE -- Miles	DIRECTION --	NEAREST TOWN Hazlehurst	
OTHER LANDMARK Behind Fire Station			
WELL PURPOSE (Home, Irrigation, Municipal, Industrial, Fish Pond, etc.) Municipal			

PUMP DATA		
PUMP TYPE:		
Submersible <input type="checkbox"/>	Turbine <input checked="" type="checkbox"/>	Jet Flowing Well <input type="checkbox"/>
Other (Describe)		
POWER TYPE:		
Electric <input checked="" type="checkbox"/>	Tractor <input type="checkbox"/>	Diesel <input type="checkbox"/>
Gasoline <input type="checkbox"/>	Butane <input type="checkbox"/>	
Other (Describe)		H/P 50
DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	3
Sand & Gravel	3	60
Clay & Sand Streaks	60	100
Clay	100	170
Sand	170	190
Clay/Sand Streaks	190	240
Sand	240	285
Clay	285	314

WELL DATA		
Well Depth 305'	Casing Diameter (In.) 18"	Casing Length (Ft.) 240'
Type of Casing Steel	Hole Depth 305'	Depth to Static 228'
TYPE OF COMPLETION:		
Underreamed <input checked="" type="checkbox"/>	Gravel Packed <input checked="" type="checkbox"/>	Natural Development <input type="checkbox"/>
Telescoped <input type="checkbox"/>	Open Hole <input type="checkbox"/>	
Other (Describe)		
WELL GROUTED TO A DEPTH OF 240' FEET		
Type Grout:		
Cement <input checked="" type="checkbox"/>	Bentonite <input checked="" type="checkbox"/>	Mix <input type="checkbox"/>

SCREEN DATA		
Diameter (In.) 12"	Length (Ft.) 40'	Slot Size (In.) 0.025"
Screen Type Stainless Steel	Depth to Bottom (Ft.) 305'	

REC'D OCT 18 2001

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

LAYNE CENTRAL
By Dave Cook 0-64
District Manager License No.

October 15, 2001
Date

Additional Information Required on Back