

8/24

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Copiah
WELL NUMBER: V-2010
DATE WELL COMPLETED: 9-5-99

NAME OF DRILLING FIRM: Crem Water Well & Supply
ADDRESS: 1318 Prichard Dr. SE
Bogue Chitto, MS 39629

NAME & MAILING ADDRESS OF LANDOWNER:
Anthony Cline
1061 Merrill Ln
Wesson
WELL LOCATION: SEC 11 TOWNSHIP 9 N RANGE 8 W
DISTANCE 3 Miles DIRECTION N of NEAREST TOWN Wesson
OTHER LANDMARK:
WELL PURPOSE: Home Irrigation

PUMP DATA
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 3/4
Pump Capacity (GPM) 10 No. of Stages 12 Setting Depth 150 FT.
PUMP TEST
Well yielded 10 GPM with a drawdown of 10 ft. after 1 hours of pumping

WELL DATA
Well Depth 210 Casing Diameter (In.) 4 Casing Length (Ft.) 190
Type of Casing PVC Hole Depth 240 Depth to Static Water Level 93

LOG DATA
TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____
Name of Organization Running Log _____

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA
Diameter - Inches 4 Length - Feet 20 Slot Size - Inches 0.10
Screen Type PVC Depth to Bottom - Feet 210

Driller's Remarks
RECEIVED
Top of Log Pipe or Reduction in Casing
FEB 01 2000
IF TELESCOPED OR MORE THAN ONE SCREEN USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Mixed Clay	0	48	Dept. of Environmental Quality Office of Land & Water Resources		
Blue Clay	48	127			
Sand	127	137			
Streaky	138	200			
Sand	200	230			
Streaky	230	240			

IF MORE SPACE IS NEEDED, USE BACK