

COVINGTON
C 25
7-15-77
E.C. #: 72

C. P. CLARK
MISSISSIPPI WATER WELL DRILLING
BOARD OF WATER COMMISSIONERS ROUTE 2
416 North State Street LAUREL, MISS. 39440
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

CODED

7/15 1977 C.P. Clark Covington
date well completed firm name county well located

LANDOWNER: Jayne Central
Jackson, Miss. (for
Okatoma Water Assoc.)
(mailing address)

WELL LOCATION:
sec. 23 T. 9 (N) R. 14 E
2 miles SW of Hotchkiss
(distance) (direction) (nearest town)

WELL PURPOSE: Test Hole Water
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 4
 - (2) total depth (feet) 725
 - (3) static water level (feet) 165 below top of ground.
 - (4) casing Black I, 638,
(material) (depth)
2 if telescope see back.
(size)
 - (5) screen 42, 659
(length) (depth to top)
2 3/4 O.D. Solid S.S. 006
(size) (material)
 - (6) pump air lift 125
(HP) (yield gpm)

(type power)
 - (7) electric log yes
(yes or no)
State Geo Survey
(organization running log)
 - (8) how well bottom plugged B.W.U

| description of formations encountered | from | to |
|---------------------------------------|------------|-------------|
| <u>Sandy Clay</u> | <u>0</u> | <u>17</u> |
| <u>Sand & silt</u> | <u>17</u> | <u>85</u> |
| <u>Sandy Clay</u> | <u>85</u> | <u>140</u> |
| <u>Clay</u> | <u>140</u> | <u>176</u> |
| <u>Sand</u> | <u>176</u> | <u>270</u> |
| <u>Clay</u> | <u>270</u> | <u>300</u> |
| <u>Sandy Clay</u> | <u>300</u> | <u>348</u> |
| <u>Sand</u> | <u>348</u> | <u>448</u> |
| <u>Clay</u> | <u>448</u> | <u>500</u> |
| <u>Clay & Silt streaks</u> | <u>500</u> | <u>594</u> |
| <u>Clay</u> | <u>594</u> | <u>657</u> |
| <u>Sand</u> | <u>657</u> | <u>689</u> |
| <u>Sandy Clay</u> | <u>689</u> | <u>706</u> |
| <u>Sand</u> | <u>706</u> | <u>725</u> |
| <u>Clay</u> | <u>725</u> | <u>1011</u> |

659
CODED
RECEIVED
AUG - 2 1977

DRILLERS REMARKS: Set air line
to 365 Sampled 3 hrs @
9:25 P.M. Capped pipe
sample to install pump for
supply for dig well

MISS. BD. OF WATER COMMISSIONERS