

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Covington	
WELL NUMBER 41	CODED <input checked="" type="checkbox"/>
DATE WELL COMPLETED 5-26-94	

PERMIT NUMBER 155
NAME OF DRILLING FIRM Griner Drilling Service, Inc.

NAME & MAILING ADDRESS OF LANDOWNER Mosbacher Energy Company		
WELL LOCATION: 6 1/2 miles S of 84 on 588		
SEC 25	TOWNSHIP 8 N S	RANGE 15 E W
DISTANCE 1/2	DIRECTION S	NEAREST TOWN Seminary
OTHER LANDMARK Alma Rogers 25-8 #1		
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.		

PUMP DATA		
PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 5		
Pump Capacity (GPM) 80	No. of Stages	Setting Depth 220' FT.
PUMP TEST Well yielded 80 GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 231 FT	Casing Diameter (In.) 4"	Casing Length (Ft.) 200'
Type of Casing PVC	Hole Depth 231	Depth to Static Water Level 176'
TYPE OF COMPLETION: (Circle One or More): Gravel Packed , Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric , Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log _____	

WELL GROUTED TO A DEPTH OF 50 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 4	Length - Feet 30'	Slot Size - Inches .010
Screen Type PVC	Depth to Bottom - Feet 231	

Driller's Remarks Wd low and well wouldn't blow much.

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
sand + beng gravel	0	100			
clay	100	180			
sand	180	231			

RECEIVED
JUN 03 1994

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK