MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Covington
WELL NUMBER	G-2019
CODED	
PERMIT NUMBER	0-586
NAME OF DRILLING FIRM	James Wells Water Well Service
DATE WELL COMPLETED	4-16-2000

NAME & MAILING ADDRESS OF LANDOWNER
TED E Crawford
84 East of Collin
Collins MS

WELL LOCATION	SEC	TOWNSHIP	RANGE
	17	8 N/S	15 E/W

DISTANCE	DIRECTION	NEAREST TOWN
4 Miles	EAST	of Collin

OTHER LANDMARK
Hx 84

WELL PURPOSE (Home, Irrigation, Municipal, Industrial, Fish Pond, etc.)

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 1½

Pump Capacity (GPM)	No of Stages	Setting Depth
		FT.

PUMP TEST

Well yielded 25 GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
60	4in	40

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	60	30

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF 15 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4in	20	8.10

Screen Type	Depth to Bottom - Feet
PVC	40-60

Top of Lap Pipe or Reduction in Casing

IF TELESCOPED OR MORE THAN ONE SCREEN USE BACK PAGE

RECEIVED
JUL 20 2000
Dept. of Environmental Quality
Office of Land & Water Resources

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	2
Clay	2	25
Sand	25	40
Pea Gravel	40	60

FORMATIONS (Continued)	FROM	TO

IF MORE SPACE IS NEEDED, USE BACK