

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Covington

WELL NUMBER 72004 CODED

DATE WELL COMPLETED
7-17-97

PERMIT NUMBER
0-586

NAME OF DRILLING FIRM
James Walls
Water Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER
Larry Flynt
Rt. 2 Box 344 B
Collins, MS 39428

WELL LOCATION SEC 12 TOWNSHIP 7 RANGE 16 E

DISTANCE 8 Miles DIRECTION NW of NEAREST TOWN Seminole

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 1

Pump Capacity (GPM) No. of Stages Setting Depth

PUMP TEST

Well yielded 10 GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth <u>70ft</u>	Casing Diameter (in.) <u>4"</u>	Casing Length (Ft.) <u>50'</u>
Type of Casing <u>PVC</u>	Hole Depth <u>70'</u>	Depth to Static Water Level <u>40'</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other

WELL GROUTED TO A DEPTH OF 15 FEET
Type Grout (circle one): Cement Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

07-30-98A09:39 RCVD

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches <u>4"</u>	Length - Feet <u>20'</u>	Slot Size - Inches <u>08</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>50'-70'</u>	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	
			FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>2</u>		
<u>Clay</u>	<u>2</u>	<u>40</u>		
<u>Sand</u>	<u>40</u>	<u>70</u>		

IF MORE SPACE IS NEEDED, USE BACK