

Covington  
 M 40  
 5/27/83  
 Log # 83

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

May 27 1983 C.P. Clark Waterwells Covington  
 date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
Bryant Nursery, 1205 W Pine St	Top soil & tan clay	0	4
Hattiesburg, Miss. (mailing address)	Red clay	4	11
	Red clay & thin gravel	11	19
	hard red gravel	19	34
	clay	34	35
	Sand & pea gravel	35	57
	Clay	57	88
	clay with sandy streaks	88	91
	Sandy clay	91	110
	Clay	110	121
	Hard hard ferr. siltstone	121	122
	Very hard siltstone	122	129
	Clay	129	134
	Sandy clay & sandstone	134	146
	Rock	146	146 1/2
	Sandy clay	146 1/2	148
	Sand	148	150
	Rock	150	157
	Hard clay	157	169
	Silt sticky clay	169	187
	Sandy clay & sand	187	210
	Sand	210	213
	Sandy clay & clay	213	279
	Clay	279	281
	Sand	281	284
	Sandy clay	284	286
	Sand	286	289 1/2
	Sandy clay & sand	289 1/2	310
	Clay	310	332
	Sandy clay, mixed	332	368
	clay with sandy streaks	368	522
	Sand	522	522
	Clay	522	574

DEPT. OF NATURAL RESOURCES  
 BUREAU OF LAND & WATER RESOURCES

JUN - 6 1983

RECEIVED

DRILLERS REMARKS:

(8) how well bottom plugged - BWW  
 & steel bearings

(7) electric log yes  
 (yes or no)  
 Bureau of Geol  
 (organization running log)

(6) pump 5 52 @ 30\*  
 (HP) (yield gpm)  
230V 1φ  
 (type power)

(5) screen 21' 500'  
 (length) (depth to top)  
2 1/2" Stainless Steel  
 (size) (material)

(4) casing Galv. 500  
 (material) (depth)  
 (size) if telescope see back.

(3) static water level (feet) 129 below  
 top of ground.

(2) total depth (feet) 521

(1) diameter (inches) 4

WELL LOCATION:  
 sec. 14 T. 6 N R. 15 E  
5 1/2 miles SE of Simona  
 (distance) (direction) (nearest town)

WELL PURPOSE: Domestic  
 (home, irrigation, municipal, industrial)

LANDOWNER: Bryant Nursery, 1205 W Pine St  
Hattiesburg, Miss.  
 (mailing address)