B1998

DeSoto

B ~~0002~~

6-19-65

MISSISSIPPI BOARD OF WATER COMMISSIONERS

WATER WELL DRILLERS LOG

Date: June 19, 19 65, Driller: Carloss Well Supply County De Soto
(Name

(1) Owner of Land: De Soto Utilities
(Name)
1 Office Park Plaza
Southaven, Mississippi
(Address)
Near Horn Lake, Miss.

(2) Location: ____¼, ____¼, Sec. ____ T ____ R ____,

____ miles ____, of ____,
(distance) (direction) (Nearest Town)

(3) Topography: Hilly
(Hilly) (Flat) (Level)

(4) Purpose of Well: Subdivision
(Domestic Irrigation Municipal, Industrial, Other)

Information upon completion of well:

(1) Diameter 6 inches.

(2) Total Depth 99 feet.

(3) Water Level 38 feet below top of ground.

(4) Cased to 59', Size 6",

(5) Screen: Size 6", Length 40'.

(6) Were any formations sealed against pollution?
Casing Cemented
____ yes, ____ no.

If YES depth of formation ____,

Why ____

Drillers Remarks: ____

Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thickness Feet	Depth Feet
Top Soil	40'	40'
Coarse Yellow Sand	20'	60'
Coarse Yellow Sand and Gravel	20'	80'
White Clay	1'-6"	81'6"
Fine Medium Sand	13'-6"	95'
Medium Sand	4'-6"	99'-6"
Blue Shale	6'-6"	106'

(Use Back Side)

Well No.

NOV - 3 1965

Mail this copy to Board of Water Commissioners 429 Miss. St. Jackson, Miss.