

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
 Bureau of Land and Water Resources

P. O. Box 10631
 Jackson, MS 39289-0631
 WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Desoto

WELL NUMBER
G-2033

DATE WELL COMPLETED
6-24-92

PERMIT NUMBER

NAME OF DRILLING FIRM
HICKS WELL CO.

RT. 1 BOX 157
 SENATOBIA, MS 38668

NAME & MAILING ADDRESS OF LANDOWNER
Dudley Snell
545 Douglless
Hernando, Ms. 38632

WELL LOCATION: SEC TOWNSHIP RANGE
34 2 N 7 W

DISTANCE DIRECTION NEAREST TOWN
5 Miles NE of Hernando

OTHER LANDMARK

WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine, Jet, Flowing Well,
 Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
 Other (Describe) H/P *1 1/2*

Pump Capacity (GPM) No. of Stages Setting Depth
23 15 180 FT.

PUMP TEST
 Well yielded *23* GPM with
 a drawdown of _____ ft.
 after _____ hours of pumping

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Fl.)
240 4" 225

Type of Casing Hole Depth Depth to Static Water Level
PVC 240 160

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
 (Describe)

Top of Lap Pipe or Reduction in Casing
 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
4" 15 013

Screen Type Depth to Bottom - Feet
PVC 15

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATION ENCOUNTERED FROM TO
<i>R. sand</i>	<i>0</i>	<i>20</i>	<p>RECEIVED JUL 27 1992 Dept. of Environmental Quality Bureau of Land & Water Resources</p>
<i>gravel</i>	<i>20</i>	<i>80</i>	
<i>clay</i>	<i>80</i>	<i>180</i>	
<i>w. sand</i>	<i>180</i>	<i>240</i>	

IF MORE SPACE IS NEEDED, USE BACK