

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

WELL LOCATED
~~MADELOT~~

WELL NUMBER
Desota

CODED
M 2088

DATE WELL COMPLETED
8-24-90

PERMIT NUMBER

NAME OF DRILLING CO.
HICKS WELL CO.

RT. 1 BOX 157
SENATOBIA, MS 38668

NAME & MAILING ADDRESS OF LANDOWNER
Bob Woods

Holly Springs

MS. 38668

WELL LOCATION: SEC _____ TOWNSHIP _____ RANGE _____

29 3 N 5 E

DISTANCE _____ DIRECTION _____ NEAREST TOWN _____

5 Miles **W** of **Watson**

OTHER LANDMARK _____

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P

Pump Capacity (GPM)	No. of Stages	Setting Depth
10	9	90 FT.

PUMP TEST

Well yielded _____ **10** _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 110	Casing Diameter (In.) 4"	Casing Length (Ft.) 100
Type of Casing PVC	Hole Depth 110	Depth to Static Water Level 60

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log _____

SCREEN DATA

Diameter - Inches 4"	Length - Feet 10'	Slot Size - Inches 0.13
Screen Type PVC	Depth to Bottom - Feet 10	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
RC	0	20	RECEIVED		
WC & S	20	90			
WS	90	110			
			NOV 13 1990		
			Department of Natural Resources Bureau of Land & Water Resources		
			IF MORE SPACE IS NEEDED, USE BACK		