

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Forrest	
WELL NUMBER A-2025	CODED
DATE WELL COMPLETED 8-9-2000	

PERMIT NUMBER
NAME OF DRILLING FIRM Boneswater Well

NAME & MAILING ADDRESS OF LANDOWNER Richard Taylor			
80 Fairway Drive			
Hattiesburg, 39402			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	36	5 S	14 E
DISTANCE	DIRECTION	NEAREST TOWN	
1/2 Miles	W	intersection of I-9+59 intersection	
OTHER LANDMARK			
WELL PURPOSE Irrigation Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible , Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric , Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 1 1/2		
Pump Capacity (GPM) 30	No. of Stages	Setting Depth _____ FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 180	Casing Diameter (In.) 4	Casing Length (Ft.) 160
Type of Casing Sch40	Hole Depth 180	Depth to Static Water Level 85
TYPE OF COMPLETION: (Circle One or More): Gravel Packed , Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric , Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log	

WELL GROUTED TO A DEPTH OF 10 FEET Type Grout (circle one): Cement , Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 4	Length - Feet 20	Slot Size - Inches #8
Screen Type Sch40	Depth to Bottom - Feet	

Driller's Remarks
Top of Lap Pipe or Production in Casing RECEIVED IN FILE
IF RECORDED OR MORE THAN ONE SCREEN USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
clay	0	180	SEP 07 2000		
SAND	120	180			

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK