

Forrest
D 44
8-66 (3)


MISSISSIPPI BOARD OF WATER COMMISSIONERS

WATER WELL DRILLERS LOG

Date: August, 19 66, Driller: Carlross Well Supply County: Forest

(Name)

(1) Owner of Land: Palmer's Crossing (Name) Utility District - Well # 2	Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thick- ness Feet	Depth Feet
(Address) Palmers Crossing, Mississippi	Top Soil	20	20
(2) Location: NE 1/4, SE 1/4, Sec. 27 T. 4 N, R. 13 W 2 miles S of Hatt.	Sand	14	34
	Clay & Sand Streaks	26	60
	Clay	60	120
	Sand & Clay	145	265
	Hard Sand	25	290
	Sand and Gravel	10	300
(3) Topography: (Hilly) (Flat) (Level)	Clay & Sand	105'	405'
(4) Purpose of Well: Municipal (Domestic Irrigation, Municipal, Industrial, Other)	Hard Clay	15	420
	Clay & Sand	57	477
	Fine Sand	48	525
Information upon completion of well:	Sand & Strks. Lignite	43	568
(1) Diameter 12 inches.	Coarse Sand	32	600
(2) Total Depth 642 feet.	Sand & Streaks Lignite	61	661
(3) Water Level 45' feet below top of ground.	Clay	15'	676
(4) Cased to 591', Size 12"	Sand	14'	690
(5) Screen: Size 8", Length 42'	Tough Clay & Sand	24	714
(6) Were any formations sealed against pollution? <input checked="" type="checkbox"/> yes, <input type="checkbox"/> no.	Clay & Thin Sand Strks.	25	739
If YES depth of formation Casing cemented for its entire length. Why Standard Procedure	White Sand	31	770
Drillers Remarks:	Gray Sand w/ Brown Strks.	35	805'



(Use Back Side)

Well No.

Mail this copy to Board of Water Commissioners 429 Miss. St. Jackson, Miss.