

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Forrest

WELL NUMBER J-2017 CODED

DATE WELL COMPLETED
July 22 1998

PERMIT NUMBER

NAME OF DRILLING FIRM
A+T Pulling

NAME & MAILING ADDRESS OF LANDOWNER
Boyer Graham
McLaurin

WELL LOCATION: SEC 4 TOWNSHIP TB RANGE SR12E

DISTANCE 10 Miles DIRECTION South of NEAREST TOWN Hbung

OTHER LANDMARK

WELL PURPOSE: Agric. Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P 1

Pump Capacity (GPM)	No. of Stages	Setting Depth
<u>6</u>		FT.

PUMP TEST

Well yielded 6 GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth <u>90</u>	Casing Diameter (In.) <u>2</u>	Casing Length (Ft.) <u>80</u>
Type of Casing <u>Pvc</u>	Hole Depth <u>90</u>	Depth to Static Water Level <u>35</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches <u>2</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>12</u>
Screen Type <u>Pvc</u>	Depth to Bottom - Feet <u>90</u>	

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<u>top soil</u>	<u>0</u>	<u>10</u>			
<u>clay</u>	<u>10</u>	<u>70</u>			
<u>sand</u>	<u>70</u>	<u>90</u>			

IF MORE SPACE IS NEEDED, USE BACK