

State Well Report

Part 1

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:		
Aquifor:		
Well #: 52		
L. S. Elevation:		
B-log #:		

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

30 days of completion of drilling of the well.			
Well Owner Information	Well Location		
Owner Name Barry Tinsley	Latitude: 31 • 33 • 165 " Longitude: 90 • 42 515 "		
Mailing Address: 4 Half Ray	Method of Lat/Long (circle one): Conventional Survey,		
	USGS quad, Hand-held GPS Survey-grade GPS		
Role: MS 39661	SE 43K/4 Sec 21 Twn 7N Rng SE		
Robe MS 3966/ City State Zip Code			
Telephone No. (601) 446-226	Distance Direction Nearest Town Miles No of Wic Call Crook.		
Well	Data		
Purpose of Well (circle one) Home Industrial Public Supply	Irrigation Fish Culture Other:		
	• • • • • • • • • • • • • • • • • • •		
Date well drilling started: \$\frac{\sqrt{7}\sqrt{0\sqrt{8}}}{2\sqrt{0}}\$ Date	well drilling completed:		
If flowing, method of flow regulation: Valve Other (c			
Static Water Level: 180 feet above of below (circle one)	land surface Date measured: \$\\\ 7\\\ \otimes \\		
Method of Measurement (circle one) steel tape electric tape	air line other:		
Hole depth: 278 Well depth: 270 Well grouted to a depth of 10 feet			
-Type of grout (circle one): Cement Bentonite Mix			
Casing length: 260 feet Casing diameter: 4			
Screen length: 10 feet Screen diameter: 4			
Screen slot size: 1010 inches Setting depth: From			
Type of completion (circle all applicable): Gravel packed Under			
Other (describe):			
Top of lap pipe or reduction in casing:feet. If telescoped or more than one screen, describe on back of page			
Logs run (circle all applicable): No log run Electric Gamma Ray	y Density Sonic Neutron Other:		
Name of organization running log(s):			
I certify that the well was drilled, constructed, and completed in			
Department of Environmental Quality and/or the Mississippi De	partment of Health regulations and state laws.		
GRENN WATER WELL & SUPPLY, INC.	De MENTE		
Brian McClendon, lic. no. 0-664	(F) (May IVI (Muser)		
Print Name of Water Well Contractor and License No.	Signature of Water Well Contractor		

RECEIVED

AUG 28 2008

BY: OLWR

_			_
Gro	บทก	ΙA	vel

Description of Formations Encountered	From	To
nodclay	0	17
		100
santgravel	\-/-	109
white clay	109	146
· · · · · · · · · · · · · · · · · · ·	146	170
blueclay	100	1.7
white clay	174	180
Rand	180	278
		+
		ļ
		
·		-
		ļ
		
		-
		ل

If more than one screen, show location of each on sketch

aid in locating the well; 3) any roads, power time	ell location; 2) any permanent structures on the property that may is, or other items that may aid in locating the property and the well;
4) indicate direction.	N xwell
	house
	and the same of th
•	Rotel
	•
Landowner Name: Barry Tinsley	

/W

Signature of Water Well Contractor

Brian McClendon, lic. no. 0-664 GRENN WATER WELL & SUPPLY, INC.

STATE WELL REPORT

Part 2

Pump Installer's Completion Report
Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210

For Office Use Only:			
Aquifer:			
Well #:	32		

SUPPLY, INC Date completed: 8 7	08	(6Ó1)	961-5210 4-6938 (fax)	Elevation:
		e pump installer in deta	il and filed with the Departme	nt within 30 days of the
installation of pump. Well Owner Information		Well Location		
Owner Name: Barry Tinsley		Latitude: 31033 168" Longitude: 90" 42 515		
Mailing Address: 4 Hall Kal		Method of Lat/Long (circle one): Conventional Survey,		
			USGS quad, Hand	held GPS, Survey-grade GPS
Rofice MS 39661 City State Zip Code Telephone No. (601) 446-2226		Distance Direction Nearest Town		
		Distance Direction Nearest Town 3 Miles N of M Call Creek		
agandraga ay arg arga arga arga arga arga arg	Pump Type Circle one			wer Type ircle one
Air Lift	Jet	Submersible	Diesel Engine Gasolin	e Engine Natural Gas
Bucket	Piston	Turbine	Electric Motor Hand	Tractor PTO
Centrifugal	Rotary	Flowing Well	Windmill Other (specify):
Other (specify):		····	Horse Power Rating of Motor:	
Date Pump Installed: 8 17/03		Setting Depth: 220 feet		
Rated Pump Capacity:	10	Gallons Per Minute	Number of Stages:15	5
F	ump Test Data			asuring Water Level
Date Well Tested:	17/08		_	
Static Water Level (A): 120 Feet Below Land Surface			suring Line Steel Tape	
Pumping Water Level (B): 187 Feet Below Land Surface		Other (specify):		
Drawdown [(B) – (A)]:	フFeet	Below Land Surface	For flowing well, measured sh	ut in head:feet
Test Pumping Rate: Gallons Per Minute		Well yielded	GPM with a drawdown of	
Duration of Pump Test (minimum 4 hours): 4 hours 7 feet after 4 hours of pumping				4 hours of pumping
I HEREBY CERTIFY tha GRENN WATER WELI WILLIAM L. HARD Print Name of Pump Insta	L & SUPPLY, IN, LIC, NO	INC. 0. 0-802	of my knowledge. Chan Hardm Signature of Pump In	staller

RECEIVED

AUG 28 2008

BY: OLWR