

30544

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

COUNTY WELL LOCATED
Franklin

WELL NUMBER
F19

DATE WELL COMPLETED
11-1-89

PERMIT NUMBER

NAME OF DRILLER
RAYBORN DRILLING, INC.

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
Fontenberry Orig Co.
P.O. Box CC
Natchez MS 39120

WELL LOCATION: SEC **25** TOWNSHIP **6 N** RANGE **1 E**
S W

DISTANCE **6** Miles DIRECTION **SW** of NEAREST TOWN **Roxie**

OTHER LANDMARK
2988' N + 2095' W of SE/Gr

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Oilfield

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe) **Air**

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe)

Pump Capacity (GPM) **50** No. of Stages **—** Setting Depth **—** FT.

PUMP TEST
Well yielded **50** GPM with
a drawdown of **—** ft.
after **—** hours of pumping

WELL DATA

Well Depth 360'	Casing Diameter (In.) 3"	Casing Length (Ft.) 340
Type of Casing Sch 40 PVC	Hole Depth 360'	Depth to Static Water Level 140'

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, **No Log Run**, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 3"	Length - Feet 20'	Slot Size - Inches .020
Screen Type Sch 40 Slotted PVC	Depth to Bottom - Feet 360'	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	10	RECEIVED AUG 06 1990 Department of Natural Resources Bureau of Land & Water Resources		
sand	10	90			
Chalk	90	315			
Sand	315	360			
FRANKLIN F19					

IF MORE SPACE IS NEEDED, USE BACK