

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED FRANKLIN	
WELL NUMBER J 48	CODED <input checked="" type="checkbox"/>
DATE WELL COMPLETED 10-26-90	

PERMIT NUMBER
NAME OF DRILLING FIRM RAYBORN DRILLING INC
Natchez, ms

NAME & MAILING ADDRESS OF LANDOWNER Pleasant Valley Baptist Church Box 78A meadville, ms			
WELL LOCATION:	SEC 9	TOWNSHIP 6 N S	RANGE 4 W
DISTANCE 2 Miles	DIRECTION S.E.	NEAREST TOWN of Edgerton	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. Home			

PUMP DATA		
PUMP TYPE (Circle One): Submersible , Turbine, Jet, Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric , Tractor, Diesel, Gasoline, Butane, Other (Describe)		
Pump Capacity (GPM) 10	No. of Stages 15	Setting Depth 50 FT.
PUMP TEST		
Well yielded 10 GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 100'	Casing Diameter (In.) 4"	Casing Length (Ft.) 90'
Type of Casing sch 40 PVC	Hole Depth 100'	Depth to Static Water Level 2'
TYPE OF COMPLETION: (Circle One or More): Gravel Packed , Underreamed, Telescoped, Natural Development , Open Hole, Other (Describe)		
Top of Lap Pipe or Reduction in Casing FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) No Log Run	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches 4"	Length - Feet 10'	Slot Size - Inches .012
Screen Type sch 40 slotted PVC	Depth to Bottom - Feet 100'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FOR (If Not Continued)	FROM	TO
TOP SOIL	0	2			
CHALK	2	15			
SAND	15	30			
CHALK	30	110			
SAND	110	130			

RECEIVED

DEC 19 1991

Dept. of Environmental Quality
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK