

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

COUNTY WELL LOCATED
Franklin

WELL NUMBER CODED
No. 15 CS

4600' BY FU USA

P.A. McKenna

GATE WELL COMPLETED
8-31-89

PERMIT NUMBER
M203050306

NAME OF DRILLING FIRM
Griner Drilling Service, Inc.

CODED

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
Amoco Production

P.O. Box 21178

Tulsa, Oklahoma 74121

WELL LOCATION: SEC **10** TOWNSHIP **5^N** RANGE **2^E**

2134' N & 889' E OF SW/4th of _____

OTHER LANDMARK
Clear Springs Field

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Oilfield Rig Supply

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine Jet Flowing Well,
Other (Describe) **5 H.P.**

POWER TYPE (Circle One):
 Electric Tractor Diesel Gasoline Butane,
Other (Describe) **330 Volt 3 phase**

Pump Capacity (GPM) **70** No. of Stages **—** Setting Depth **315'** FT.

PUMP TEST

Well yielded **70** GPM with
a drawdown of **—** ft.
after **—** hours of pumping

WELL DATA

Well Depth **360'** Casing Diameter (In.) **330'** Casing Length (Ft.) **220'**

Type of Casing **PVC** Hole Depth **360'** Depth to Static Water Level **120'**

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed Underreamed Telescoped,
 Natural Development Open Hole Other
(Describe)

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run Electric Gamma Ray Density Sonic Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches **4"** Length - Feet **30'** Slot Size - Inches **.010**

Screen Type **PVC** Depth to Bottom - Feet **330' - 360'**

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
clay	0	63			
sand, clay	63	200			
clay	200	275			
sand	275	360			

IF MORE SPACE IS NEEDED, USE BACK