

MISSISSIPPI BOARD OF WATER COMMISSIONERS

13' head in 15" tile = 9.1 GAL PER FOOT OR 118.3 GALLONS
 FRANKLIN WATER WELL DRILLERS

Date: 3-17-64/17/1964, Driller: Roy Chandler, Franklin County
 (Name)

CODED

FRANKLIN

(1) Owner of Land: MCNROE HOLLAND
 (Name)
R.F.D. EDDICETON - MISS
 (Address)

(2) Location: 2+11 1/4, 5 R 7 1/4, Sec. T 5 R 7
8 miles S.W. EDDICETON of
 (distance) (direction) (Nearest Town)

(3) Topography: (Milly) (Flat) (Level)

(4) Purpose of Well: None
 (Domestic Municipal Irrigation Industrial, Other)

Information upon completion of well:
 APR 8 1964
 MISS. BOARD OF WATER COMMISSIONERS

(1) Diameter 15 inches. hole
ROCK PACKED AROUND

(2) Total Depth 68 feet. TILES

(3) Water Level 55 feet below top of ground.

(4) Cased to 68', Size 15" ID.

(5) Screen: Size NONE, Length ---

(6) Were any formations sealed against pollution?
no.

If YES depth of formation 3' OR 4'

Why hold out rain & drainage water

Drillers Remarks: well produces 1/2 gallons only per minute.

Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thick-ness Feet	Depth Feet
yellow clay	6	6'
clay gravel	25	25'
2) very pipe clay	20	20'
RED PIPE CLAY	1	1'
FINE TIGHT WATER SAND	2	2'
all colors MIXED	14	14'
Multiple color		
Blue green streaked pipe CLAY		
lesion or big		
Cement tile		
well, with		
approximately		
100 GAL WATER		
ON DEMAND		
with a Recovery		
Rate at 1/2		
gallons per		
minute - weak		
but plenty good		
water that will		
furnish a home		

(Use Back Side)

Well No.