

Scarf

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631

Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

15-30-95
 DATE WELL COMPLETED
 2/11

PERMIT NUMBER
 0408
 NAME OF DRILLING FIRM
 Fry Eagle Well Serv
 1941 Depot Rd
 Hattiesburg MS 39452

NAME & MAILING ADDRESS OF LANDOWNER
 Randy Eubanks
 Rt 3 Box 22
 Lucedale MS 39452
 WELLS LOCATION SEC 34 T10 R5 E
 DISTANCE 7 Miles East of Lucedale
 OTHER LANDMARK
 Farm
 WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
 Water Cams

PUMP DATA
 PUMP TYPE (Circle One):
 Submersible Turbine Jet Flowing Well
 Other (Describe)
 POWER TYPE (Circle One):
 Electric Tractor Diesel Gasoline Butane
 Other (Describe) H/P
 Pump Capacity (GPM) No. of Stages Setting Depth
 10 4 120 FT.
 PUMP TEST
 Well yielded 20 GPM with
 a drawdown of 10' ft.
 after 1/2 hours of pumping

WELL DATA
 Well Depth 240 Casing Diameter (In.) 4" Casing Length (Ft.) 230
 Type of Casing PVC Hole Depth 240 Depth to Static Water Level 110
 TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed Underreamed Telescoped
 Natural Development Open Hole Other
 (Describe) air jet
 WELL GROUTED TO A DEPTH OF 20 FEET
 Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA
 TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)
 Name of Organization Running Log

SCREEN DATA
 Diameter - Inches 4" Length - Feet 10' Slot Size - Inches #8
 Screen Type Wrapped Depth to Bottom - Feet 240

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

 Driller's Remarks
 Top of Lap Pipe or Reduction in Casing
 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	5
Clay	5	20
Sand	20	40
Clay	40	60
Clay	60	100
Clay	100	200
Chalky	200	220
Clay & Sand	220	240

FORMATIONS ENCOUNTERED TO
RECEIVED
 JUL 06 1995
 Dept. of Environmental Quality
 Office of Land & Water Resources
 IF MORE SPACE IS NEEDED, USE BACK