MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: George	PERMIT NUMBER: 0408
WELL NUMBER: E 210 CODED	NAME OF DRILLING FIRM: Fryfogle Well Sand
DATE WELL COMPLETED: 5-25-98	194 Depot Rd Ruredale MS 39452

NAME & MAILING ADDRESS OF LANDOWNER
Otis O'neal
2129 Beep Creek Rd
Ruredale MS 39452

WELL LOCATION: Bendale | SEC: 9 | TOWNSHIP: T2 N | RANGE: R8 E

DISTANCE: 3 Miles | DIRECTION: N + E | NEAREST TOWN: of Bendale

OTHER LANDMARK: Close to Cypress Center

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Pond.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 1

Pump Capacity (GPM)	No. of Stages	Setting Depth
20	7	60 FT.

PUMP TEST
Well yielded 38 GPM with a drawdown of 5' ft. after 2 hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
60'	4"	50'

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	60'	40

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) air lift

WELL GROUTED TO A DEPTH OF 20 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4"	10'	~~16~~ 8

Screen Type	Depth to Bottom - Feet
PVC Wrapped	60'

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing
FEET — IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	5			
Sandy Clay	5	20			
Sheetrock Soft Clay	20	40			
Clay	40	50			
Sand	50	60			
			IF MORE SPACE IS NEEDED, USE BACK		