

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
George

WELL NUMBER
G-99

CODED

PERMIT NUMBER

DATE WELL COMPLETED
3-28-03

NAME OF DRILLING FIRM
Coast Water Well Service

NAME & MAILING ADDRESS OF LANDOWNER
Marcus French
Pistol Howell Rd.

Latitude:
Longitude: Lucedale, MS

WELL LOCATION SEC TOWNSHIP RANGE
18 2 6

DISTANCE DIRECTION NEAREST TOWN
3 Miles SW of Lucedale

OTHER LANDMARK

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>2</u>
<u>Orange Clay</u>	<u>2</u>	<u>10</u>
<u>Brown Coarse Sand</u>	<u>10</u>	<u>40</u>
<u>White + Orange Clay</u>	<u>40</u>	<u>55</u>
<u>White Coarse Sand</u>	<u>55</u>	<u>87</u>

RECEIVED
APR 11 2008
BY: OLWR

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

WELL DATA

Well Depth <u>87'</u>	Casing Diameter (In.) <u>2"</u>	Casing Length (Ft.) <u>77'</u>
Type of Casing <u>PVC</u>	Hole Depth <u>87'</u>	Depth to Static Water Level <u>40'</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <u>2"</u>	Length - Feet <u>10'</u>	Slot Size - Inches <u>.008</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>87'</u>	

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Jack Ridgelle 472
Signature of Licensed Driller and License No.

4/9/03
Date

Additional Information Required On Back