

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED <i>Itawamba</i>	
WELL NUMBER <i>G-113</i>	CODED
PERMIT NUMBER	
NAME OF DRILLING FIRM <i>Truffel Well Service</i>	
DATE WELL COMPLETED <i>12-8-03</i>	

NAME & MAILING ADDRESS OF LANDOWNER
*Paul Nixon
219 Jolly Park Dr
Lucedale, MS 39452*

Latitude: *30° 50' 32" N*
Longitude: *089° 39' 07" W*

WELL LOCATION: SEC *26* TOWNSHIP *T2 N* RANGE *R6 E*

DISTANCE *3* Miles DIRECTION *S* of NEAREST TOWN *Central*

OTHER LANDMARK
1/2 mile E Basin Point Rd to Jolly Park Dr

WELL PURPOSE: *Shop*

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P *11/2*

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<i>top sand</i>	<i>0</i>	<i>5</i>
<i>Clay</i>	<i>5</i>	<i>22</i>
<i>sand</i>	<i>25</i>	<i>50</i>

WELL DATA

Well Depth <i>50'</i>	Casing Diameter (In.) <i>4"</i>	Casing Length (Ft.) <i>40</i>
Type of Casing <i>PVC40</i>	Hole Depth <i>50</i>	Depth to Static Water Level <i>20</i>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

WELL GROUTED TO A DEPTH OF *10* FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <i>4"</i>	Length - Feet <i>10</i>	Slot Size - Inches <i>#10</i>
Screen Type <i>PVC wrapped</i>	Depth to Bottom - Feet <i>50'</i>	

RECEIVED

JAN 08 2004

BY: OLWR

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Michael R Truffel 10408 *1-5-04*
Signature of Licensed Driller and License No. Date

Additional Information Required On Back