

STATE WELL REPORT

269

County: George
 Permit #: MS-GW-174103
 Driller: MIKE WEADE
 Date drilling completed: 7/24/19

Part 1
Driller's Log
 Mississippi Department of Environmental Quality
 Office of Land and Water Resources
 P.O. Box 2309
 Jackson, MS 39225-2309
 (601)961-5555
 (601)961-5228 (fax)

For Office Use Only:

Well #: G 234
 Aquifer: _____
 E-Log #: _____

State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.

Well Owner Information <small>(Landowner if borehole is not for a water well)</small>	Well or Borehole Location
Owner Name: <u>Kendall Stringfellow</u>	Latitude: <u>30°59'31"W</u> Longitude: <u>88°33'06"W</u>
Mailing Address: <u>1190 Shipman Firetower</u>	Method of Lat/Long (check one): Conventional Survey _____, USGS quad _____, Hand-held GPS _____, Survey-grade GPS _____
<u>Woodale</u> MS <u>39452</u>	<u>SW</u> ¼ <u>NE</u> ¼, Sec <u>24</u> T <u>2S</u> R <u>6W</u>
City State Zip Code	<u>3.99</u> Miles <u>SE</u> of <u>Woodale</u>
Telephone No. () _____	(Distance) (Direction) (Nearest Town)

Well / Borehole Data

Date drilling started: 7/22/19 Date drilling completed: 7/24/19 Hole depth: 270 Hole diameter: 9 1/2

Location of the source of any surface water used for drilling: None

Method of dosing and volume of Chlorine used in drilling and development: _____

Logs run (check all applicable): log run Electric Gamma Ray Density Sonic Neutron Other: _____

Name of organization running log(s): None

Purpose of borehole (check one): Water Well Geotechnical/Geological Investigation Ground Source Heat Pump Seismic Survey Other (describe) _____

If drilling is not related to water well construction, skip the remainder of this block

Purpose of Well (check all applicable): Home Industrial Public Supply Irrigation Fish Culture

Other (describe): _____

If a flowing well, method of flow regulation: Valve _____ Other (describe) _____

Static Water Level: 1100 feet above or below land surface Date measured: _____
(check one)

Method of measurement (check one) Steel tape Electric tape Air line Other (describe): _____

Well depth: 270 Well grouted to a depth of: 200 feet Type of grout (check one) Neat Cement Bentonite Mix

Casing length: 240 feet Casing diameter: 6 inches Type of casing: SCH 40

Screen length: 30 feet Screen diameter: 6 inches Type of screen: WRAP

Screen slot size: .14 inches Setting depth: From 240 feet to 270 feet

Type of completion (check all applicable) gravel packed Underreamed Open hole Natural Development

Other (describe): _____

Top of lap pipe or reduction in casing: _____ feet

If telescoped or more than one screen, describe on next page

RECEIVED
 AUG 26 2019

STATE WELL REPORT

Part 2

Pump Installer's Completion Report
 Mississippi Department of Environmental Quality
 Office of Land and Water Resources
 P.O. Box 2309
 Jackson, MS 39225-2309
 (601)961-5210
 (601) 360-0535 (fax)

For Office Use Only:

Well #: G 234
 Aquifer: _____

County: George
 Permit #: MS-GW-17463
 Driller: Mike + Wade
 Date completed: 7/29/19
Copy information from block on Part 1

This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.

Well Owner Information	Well Location
Owner Name: <u>Kendall Stringfellow</u>	Latitude: <u>30°52'37"N</u> Longitude: <u>88°33'06"W</u>
Mailing Address: <u>1190 Shipman Firetower</u>	Method of Lat/Long (check one): Conventional Survey _____, USGS quad _____, Hand-held GPS _____, Survey-grade GPS _____
<u>Wredate</u> MS <u>39452</u>	<u>SW</u> ¼ <u>NE</u> ¼, Sec. <u>14</u> T. <u>AS</u> R. <u>6W</u>
City State Zip Code	<u>3.99</u> Miles <u>SE</u> of <u>Wredate</u>
Telephone No. () _____	(Distance) (Direction) (Nearest Town)

Pump Type (check one)

Submersible Turbine Air Lift Centrifugal Flowing Well Jet Piston Rotary Other (describe): _____

Date Pump Installed: 7/29/19 Rated Pump Capacity: 250 Gallons Per Minute

Is This Pump (check one): New Repaired Replacement

Power Type (check one)

Electric Diesel Gasoline Natural Gas Tractor PTO Windmill Other (describe): _____

Horse Power Rating of Motor: 25 Setting Depth: 100 feet Number of Stages: 8

Pump Test Data for Non Flowing Well

Date Well Tested: 7/26/19 Duration of Pump Test (minimum 4 hours): 4 hours

Static Water Level (A): 160 Feet Below Land Surface Pumping Water Level (B): 168 Feet Below Land Surface

Drawdown [(B) - (A)]: 8 Feet Below Land Surface Test Pumping Rate: 300 Gallons Per Minute

Method of measurement (check one): Steel tape Electric tape Air line Other (describe): _____

Pump Test Data for Flowing Well

Measured shut in head: _____ feet.

Well yielded _____ GPM with a drawdown of _____ feet after _____ hours of pumping

Meter Installation

Meter Manufacturer: _____ Meter Serial Number: _____

Meter Model Number/Name: _____ Type of Meter: _____

Totalizer Register Unit and Multiplier Factor (AF x .001, gal x 1000, etc): _____

Installation Date: _____ Meter installed by: _____

Is This Meter (check one): New Repaired Replacement

Important: By submitting the above information you are certifying that this meter was installed to manufacturer standards. For agricultural wells, a list of approved meters is on the MDEQ website.

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

Michael R. Fruitt 8-19-19 Michael R. Fruitt
 Print Name of Pump Installer and License No. (if applicable) Date Signature of Pump Installer



STATE OF MISSISSIPPI

Department of Environmental Quality

Office of Land and Water Resources

P.O.Box 2309

Jackson, Mississippi 39225

PERMIT

TO DIVERT OR WITHDRAW FOR BENEFICIAL USE THE PUBLIC WATERS

This permit is issued to the landowner named below in accordance with the provisions of the Mississippi Water Laws, Mississippi Code Sections 51-3-1, et seq.(1972, as amended), and the regulations and standards as promulgated thereunder. Whether or not specifically named in this permit or in the applications for this permit, anyone using water from the diversion/withdrawal point described below shall do so in compliance with the provisions of this permit. Neither this permit, nor any authority conferred hereby, may be sold, conveyed, encumbered, assigned or otherwise alienated, for any period of time or under any conditions whatsoever. This permit may not be modified, transferred, or revoked without prior action by the Permit Board. Any attempts to modify, transfer or revoke this permit, or to take any other action on this permit, shall be invalid and unenforceable and may result in immediate revocation or suspension of this permit. The holder of this permit shall at all times be responsible for adherence to the terms and conditions of this permit. No agreement between the permit holder and any other party shall affect the obligations and liabilities of the permit holder. Water use under this permit is allowed only when the streamflow or lake level elevation (whichever, if any, is applicable) is above the established minimum, pursuant to Mississippi Code Section 51-3-7. Authorization is hereby granted to divert/withdraw water for the beneficial use designated herein, and for no other purpose, subject to the following terms, conditions, and limitations:

Permit Number: MS-GW-17463

Landowner Name: STRINGFELLOW, KENDALL
Landowner Address: 1190 SHIPMAN FIRETOWER
LUCEDALE, MS 39452

Source of Water: MIOCENE AQUIFER SYSTEM

Beneficial Use(s): IRRIGATION

Diversion/Withdrawal Location: SE 1/4 of the NE 1/4 **Section:** 14 **Township:** 02S **Range:** 06W
County: GEORGE **Quad:** LUCEDALE

Permitted Volume: Annual: 80.0000 Acre-feet equivalent to Daily: 0.0714 Million Gallons

Maximum Pumping Rate: 300.00 Gallons/Minute


Applicant Name: STRINGFELLOW, KENDALL
Applicant Address: 1190 SHIPMAN FIRETOWER
LUCEDALE, MS 39452

Date Permit Issued: 07/15/2019
Date Permit Expires: 07/15/2029
Date Permit Modified:
Date Permit Reissued:

This permit shall be deemed null and void if construction has not begun within one (1) year of permit issue date.

RECEIVED

AUG 25 2019


Gary C. Rikard Executive Director
Mississippi Department of Environmental Quality