

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631

Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED

WELL NUMBER

CODED

PERMIT NUMBER

NAME OF DRILLING FIRM

DATE WEYL COMPLETED

0403

Trylog Well Ser.

1199 Depot Rd

Rosedale MS 39452

Benny

CA 2112

7-15-98

NAME & MAILING ADDRESS OF LANDOWNER

Robert Green

193 Coaks Corner Rd

Rosedale MS 39452

WELL LOCATION SEC 26 T2 N R6 E

DISTANCE 6 Miles DIRECTION S of NEAREST TOWN Lumberton

OTHER LANDMARK Coaks Corner Road to 63

WELL PURPOSE, Home, Irrigation, Municipal, Industrial, Fish Pond, etc

th

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 1/2

Pump Capacity (GPM) 10 No. of Stages 6 Setting Depth 70 FT.

PUMP TEST Well yielded 18 GPM with a drawdown of 5' ft. after 1/2 hours of pumping

WELL DATA

Well Depth 70' Casing Diameter (In.) 4" Casing Length (Ft.) 60

Type of Casing PVC Hole Depth 70 Depth to Static Water Level 50'

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) air lift

WELL GROUTED TO A DEPTH OF 10 FEET Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Table with columns: Surface Elev., Geologic Unit, Unit Thickness, Depth to Top, Subs. SWL, Date, Analysis, Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches 4" Length - Feet 10' Slot Size - Inches #8

Screen Type Wrapped PVC Depth to Bottom - Feet 70'

Table with columns: DESCRIPTION OF FORMATIONS ENCOUNTERED, FROM, TO, FORMATIONS (Continued), FROM, TO. Includes handwritten entries like Sand 0-5, 5-20, 20-40, 40-55, 55-58, 58-70.

IF MORE SPACE IS NEEDED, USE BACK