MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Green	
WELL NUMBER: F 2007	CODED
4-12 98	
DATE WELL COMPLETED: 4-30-98	
PERMIT NUMBER: 0408	
NAME OF DRILLING FIRM: Fulfale Well	
194 Depot Rd	
Ruceedale MS 39452	

NAME & MAILING ADDRESS OF LANDOWNER
Quentin Walley
RT. 1 Box 160 A
Leakesville MS 39451

WELL LOCATION: Overby SECTION: 32 TOWNSHIP: 4 (N) S RANGE: 7 (E) W

DISTANCE: 1 Miles DIRECTION: S of NEAREST TOWN: Overby

OTHER LANDMARK:

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
tb

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, (Jet) Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) / H/P

Pump Capacity (GPM)	No. of Stages	Setting Depth
10	2	80 FT.

PUMP TEST

Well yielded 10 GPM with a drawdown of 5 ft. after 1/2 hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
100'	2"	90'
Type of Casing	**Hole Depth**	**Depth to Static Water Level**
PVC	100'	78'

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) air lift

WELL GROUTED TO A DEPTH OF 20 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
2"	10"	#8
Screen Type		**Depth to Bottom - Feet**
Wrapped		100'

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	5			
Clay	5	20			
"	20	40			
"	40	60	08-18-98 9:32 RCVD		
Fine Sand	60	80			
Med Sand	80	100			
			IF MORE SPACE IS NEEDED, USE BACK		