

**MISSISSIPPI
BOARD OF WATER COMMISSIONERS**
416 North State Street
Jackson, Mississippi 39201

CODED

Greene
2-11-74

WATER WELL DRILLERS LOG

Dec 11, 1974 Paul D. Drilling & Supply Greene
date well completed firm name county well located

Trusty State Street
LANDOWNER: Trusty Comm.

708 North State Street
Jackson (mailing address)

WELL LOCATION: 13P
sec. 8 T. 4N R. 5E
6 miles S of State Line
(distance) (direction) (nearest town)

WELL PURPOSE: drinking
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

(1) diameter (inches) 4"

(2) total depth (feet) 149'

(3) static water level (feet) 24' below above
top of ground.

(4) casing PVC 132'
(material) (depth)

4' if telescope see back.
(size)

(5) screen 10' 138'
(length) (depth to top)

2 3/8" S.S. halot
(size) (material)

(6) pump 3/4 15
(HP) (yield gpm)

elec
(type power)

(7) electric log yes
(yes for no)

Misc. Dev. Agency
(organization running log)

(8) how well bottom plugged steel casing

description of formations encountered	from	to
red clay & chert	0	23
red sandstone & chert	23	38
blue chert	38	57
soft blue sand & chert	57	63
blue chert	63	86
cherty sand	86	96
blue chert	96	96
soft chert & sand	96	102
blue sand	102	105
blue chert	105	114
soft chert & blue sand	114	120
blue sand & chert	120	144
chert & sand	144	149
blue chert	149	172
blue sand	172	174
white & chert	174	177
brown blue sand	177	193
blue chert	193	240

DRILLING

MAR - 9 1975

BD. OF WATER COMM

DRILLERS REMARKS: