

Greene
K 9
6-24-70

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

June 24, 1970 *Hoertel's Well Service* *Greene*
date well completed firm name county well located

LANDOWNER: *Bud Walley*
Seaberville, Miss.
(mailing address)

WELL LOCATION:
sec. 12 T. 3 N. R. 7 E.
12 miles NW of Seaberville
(distance) (direction) (nearest town)

WELL PURPOSE: home
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 2"
- (2) total depth (feet) 112 ft.
- (3) static water level (feet) 4' below above top of ground.
- (4) casing P.V.C., 102 ft.
(material) (depth)
2" If telescope see back.
(size)
- (5) screen 10 ft., 102 ft.
(length) (depth to top)
2", P.V.C.
(size) (material)
- (6) pump 1 1/2 hp., 12 gpm.
(HP) (yield/gpm)
electric
(type power)
- (7) electric log no
(yes or no)
(organization running log)
- (8) how well bottom plugged 2" pipe plug

description of formations encountered	from	to
<i>top soil</i>	<i>0</i>	<i>1</i>
<i>Clay (red & yellow, sandy)</i>	<i>1</i>	<i>5</i>
<i>sand (coarse, white)</i>	<i>5</i>	<i>19</i>
<i>clay (blue, brown, grey)</i>	<i>19</i>	<i>90</i>
<i>clay (grey w/ sand streak)</i>	<i>90</i>	<i>102</i>
<i>sand (fine, grey)</i>	<i>102</i>	<i>112</i>
<i>blue clay</i>	<i>112</i>	<i>113</i>

CODED

JUN 26 1970

MISS. BD. OF
WATER COMM.

DRILLERS REMARKS: *well test pumped 35 gpm with pump on reg*