

Greene
K23
8/3/74
AUG

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

CODED

1974 3 Haestels Well Service Greene
date well completed firm name county well located

LANDOWNER: <u>Robert Walley</u> <u>Leakesville, Miss</u> (mailing address)	description of formations encountered	from	to
WELL LOCATION: sec. <u>15</u> T. <u>3</u> (N) S R. <u>7</u> E (W) <u>10</u> miles <u>NW</u> of <u>Leakesville</u> (distance) (direction) (nearest town)	<u>top soil</u>	<u>0</u>	<u>1</u>
	<u>yellow clay</u>	<u>1</u>	<u>12</u>
	<u>bandy clay</u>	<u>12</u>	<u>26</u>
	<u>sand</u>	<u>26</u>	<u>28</u>
	<u>grey clay</u>	<u>28</u>	<u>43</u>
	<u>clay with sand str.</u>	<u>43</u>	<u>56</u>
	<u>med to coarse white sand</u>	<u>56</u>	<u>87</u>
WELL PURPOSE: <u>home</u> (home, irrigation, municipal, industrial)			
WELL COMPLETION DATA: (1) diameter (inches) <u>2"</u> (2) total depth (feet) <u>80 ft.</u> (3) static water level (feet) <u>24 ft.</u> ^(below) above top of ground. (4) casing <u>2" P.V.C.</u> <u>70 ft.</u> (material) (depth) <u>2"</u> if telescope see back. (size) (5) screen <u>10 ft.</u> <u>70 ft.</u> (length) (depth to top) <u>2"</u> <u>P.V. C.</u> (size) (material) (6) pump <u>1</u> <u>10 gpm</u> (HP) (yield/gpm) <u>electric</u> (type power) (7) electric log <u>No</u> (yes or no) (organization running log) (8) how well bottom plugged <u>2" back</u> <u>wash valve</u>			
DRILLERS REMARKS: <u>well</u> <u>yielded 20 gpm on test</u>			

CODED

RECEIVED
SEP 12 1974
MISS. BD. OF WATER COMMISSIONERS