MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Green
WELL NUMBER	N 2018
CODED	
PERMIT NUMBER	0408
NAME OF DRILLING FIRM	Fry Fogle Well Ser
	194 Depot Rd
	Lucedale MS 39452
DATE WELL COMPLETED	2-20-96

NAME & MAILING ADDRESS OF LANDOWNER
Shirley Moody
HC1 Box 47
Neely MS 39461

WELL LOCATION	SEC	TOWNSHIP	RANGE
	25	T3 N S	R9 E W

DISTANCE	DIRECTION	NEAREST TOWN
3 1/2 Miles	north	of Neely

OTHER LANDMARK
Pass old Fish house

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 1

Pump Capacity (GPM)	No. of Stages	Setting Depth
10	2	80' FT.

PUMP TEST

Well yielded 10 GPM with a drawdown of 10 ft. after 1 1/2 hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
80'	2"	75'

Type of Casing	Hole Depth	Depth to Static Water Level
PVC		

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF 20 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing
FEET — IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
2'	10'	#8

Screen Type	Depth to Bottom - Feet
Wrapped PVC	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	5			
Clay	5	20			
Sand	20	40			
Clay	40	60			
Clay	60	70			
Sand	70	92			
Tan Clay	80	92			
			IF MORE SPACE IS NEEDED, USE BACK		