

Greene  
 37  
 479

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

**CODED**

WATER WELL DRILLERS LOG

date well completed 19 Howard Well Service firm name Greene county well located

| LANDOWNER:  | description of formations encountered | from       | to         |
|---|---------------------------------------|------------|------------|
| <u>Green Lodge Methodist Church</u><br><u>Box 8</u>                       | <u>Clay</u>                           | <u>0</u>   | <u>90</u>  |
| <u>Lucedale Miss 39452</u><br>(mailing address)                           | <u>fine sand</u>                      | <u>90</u>  | <u>95</u>  |
|   | <u>Clay + Shaly Sand</u>              | <u>95</u>  | <u>220</u> |
|   | <u>Coarse Sand</u>                    | <u>220</u> | <u>240</u> |
| <b>WELL LOCATION:</b>   |                                       |            |            |
| sec. <u>2</u> T. <u>1</u> N. R. <u>7</u> E                                |                                       |            |            |
| <u>12</u> miles <u>SW</u> of <u>Lucksville</u>                            |                                       |            |            |
| (distance) (direction) (nearest town)                                     |                                       |            |            |
| <b>WELL PURPOSE:</b> <u>church</u>  |                                       |            |            |
| (home) irrigation, (municipal) industrial                                 |                                       |            |            |
| <b>WELL COMPLETION DATA:</b>  |                                       |            |            |
| (1) diameter (inches) <u>2"</u>   |                                       |            |            |
| (2) total depth (feet) <u>240</u>   |                                       |            |            |
| (3) static water level (feet) <u>90</u> <u>below</u> above top of ground. |                                       |            |            |
| (4) casing <u>PVC</u> <u>230'</u>   |                                       |            |            |
| (material) (depth)  |                                       |            |            |
| <u>2</u> if telescope see back.   |                                       |            |            |
| (size)  |                                       |            |            |
| (5) screen <u>10'</u> <u>230'</u>   |                                       |            |            |
| (length) (depth to top)   |                                       |            |            |
| <u>2</u> <u>PVC</u>   |                                       |            |            |
| (size) (material)   |                                       |            |            |
| (6) pump <u>1/2 HP</u> <u>450 gpm</u>                                     |                                       |            |            |
| (HP) (yield gpm)  |                                       |            |            |
| <u>Jet Pump</u> <u>8</u>  |                                       |            |            |
| (type power)  |                                       |            |            |
| (7) electric log <u>no</u>  |                                       |            |            |
| (yes or no)   |                                       |            |            |
| (organization running log)  |                                       |            |            |
| (8) how well bottom plugged <u>PVC</u>                                    |                                       |            |            |
| <u>B. Wilkerson</u>   |                                       |            |            |
| <b>DRILLERS REMARKS:</b>  |                                       |            |            |

**CODED**

Miss. Board of Water Comm.

JUN 29 1979

**RECEIVED**