

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Greene	
WELL NUMBER T 2043	CODED
DATE WELL COMPLETED 9-22-98	

PERMIT NUMBER
NAME OF DRILLING FIRM Pierce Well

NAME & MAILING ADDRESS OF LANDOWNER Doris McLeod			
WELL LOCATION Leakesville, Ms			
SEC	TOWNSHIP	RANGE	
23	1	(N) S	6 (E) W
DISTANCE	DIRECTION	NEAREST TOWN	
3 Miles	N	of George Co. Line	
OTHER LANDMARK			
WELL PURPOSE <u>Home</u> , Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric , Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 1		
Pump Capacity (GPM)	No. of Stages	Setting Depth
10	2	50 FT.
PUMP TEST		
Well yielded _____ 10 GPM with		
a drawdown of _____ 10 ft.		
after _____ 1 hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
65'	2"	55
Type of Casing	Hole Depth	Depth to Static Water Level
Plastic	65'	50'
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development , Open Hole, Other (Describe) _____		
WELL GROUTED TO A DEPTH OF 15 FEET Type Grout (circle one): Cement, Bentonite, Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, No Log Run , Neutron, Other (Describe) _____	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
2"	10 1/2	006
Screen Type	Depth to Bottom - Feet	
Plastic	65'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	10
clay	10	45
good sand	45	65

RECEIVED	
NOV 25 1998	
Dept. of Environmental Quality Office of Land & Water Resources	
IF MORE SPACE IS NEEDED, USE BACK	