

GRENADE
H 99
6-10-77
E Log # 75

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

Test # 1

WATER WELL DRILLERS LOG

6-10- 1977
 date well completed

Leaper
 firm name

Grenada
 county well located

LANDOWNER: New Hospital
City of Grenada -
Grenada, Miss -
 (mailing address)

description of formations encountered

from to

<u>Silt & sand</u>	<u>0</u>	<u>10</u>
<u>sand</u>	<u>10</u>	<u>20</u>
<u>sand</u>	<u>20</u>	<u>30</u>
<u>Sand & clay -</u>	<u>30</u>	<u>40</u>
<u>sand & clay</u>	<u>40</u>	<u>50</u>
<u>Clay -</u>	<u>50</u>	<u>60</u>
<u>Clay & lignite</u>	<u>60</u>	<u>70</u>
<u>Clay & lignite</u>	<u>70</u>	<u>120</u>
<u>Clay & lignite</u>	<u>120</u>	<u>130</u>
<u>Brown & white sand</u>	<u>130</u>	<u>140</u>
<u>White sand -</u>	<u>140</u>	<u>270</u>
<u>Sand & clay -</u>	<u>270</u>	<u>305</u>

WELL LOCATION:

sec. 19 T. 22 N. R. 5 E. W.
in City
 (distance) miles (direction) of (nearest town)

WELL PURPOSE: Test
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 6
- (2) total depth (feet) 305
- (3) static water level (feet) 15 below above top of ground.
- (4) casing 6 (material) (depth) (size) if telescope see back.
- (5) screen (length) (depth to top) (size) (material)
- (6) pump (HP) (yield gpm) (type power)
- (7) electric log yes (yes or no)
State Geo. Survey (organization running log)
- (8) how well bottom plugged _____

CODED

*Test pumped
 2:50 P.M.
 all material removed*

RECEIVED
 JUN 21 1977

DRILLERS REMARKS:

MISS. BD. OF WATER COMMISSIONERS