

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL
QUALITY**

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Hancock	
WELL NUMBER H 2	CODED
K 2898	
DATE WELL COMPLETED 8-8-96	

PERMIT NUMBER
NAME OF DRILLING FIRM Arnold Fincher Sr

NAME & MAILING ADDRESS OF LANDOWNER Bay St. Louis Soccer Assoc Human Res. Building Bay St. Louis, MS			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	27	8 N	14 E
DISTANCE	DIRECTION	NEAREST TOWN	
		Bay St. Louis	
OTHER LANDMARK Behind Human Res Building			
WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): <u>Submersible</u> Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): <u>Electric</u> Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 3		
Pump Capacity (GPM)	No. of Stages	Setting Depth
30	14	120 FT.
PUMP TEST		
Well yielded 30 GPM with a drawdown of 30 ft. after 12 hours of pumping		

WELL DATA		
Well Depth 150	Casing Diameter (In) 4"	Casing Length (Ft) 120
Type of Casing PVC	Hole Depth 150	Depth to Static Water Level 30

LOG DATA	
TYPE OF LOG RUN (Circle One): <u>No Log Run.</u> Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log	

TYPE OF COMPLETION: (Circle One or More): <u>Natural Development</u> Gravel Packed, Underreamed, Telescoped, Open Hole, Other			
WELL GROUTED TO A DEPTH OF 20 FEET Type Grout (circle one): Cement, Bentonite, or Mix			

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 4	Length - Feet 30	Slot Size - Inches .008
Screen Type PVC	Depth to Bottom - Feet 150	

Driller's Remarks
Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN, USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Sand	0	10
Clay	10	45
Sand	45	60
Clay	60	90
Sand	90	150

RECEIVED

AUG 19 1996

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK

