

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED HANCOCK	
WELL NUMBER M 2118	CODED 24
DATE WELL COMPLETED 9-12-94	

PERMIT NUMBER 0239
NAME OF DRILLING FIRM McGILL PUMP & WELL

NAME & MAILING ADDRESS OF LANDOWNER TIM MEYER			
6000 DIRTY DOG RD.			
BAY ST. LOUIS			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	7	9	N 15 E
DISTANCE	DIRECTION	NEAREST TOWN	
6 Miles	West	Waterland	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, (Jet) Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): (Electric) Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 1		
Pump Capacity (GPM) 12	No. of Stages 2	Setting Depth 40' FT.
PUMP TEST		
Well yielded 12 GPM with a drawdown of 7 ft. after 1 hours of pumping		

WELL DATA		
Well Depth 240'	Casing Diameter (In) 2"	Casing Length (Ft.) 230'
Type of Casing PVC	Depth to Static Water Level 300'	10'

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
(No Log Run)	
Name of Organization Running Log	

TYPE OF COMPLETION: (Circle One or More): (Natural Development) Underreamed, Telescoped, Gravel Packed, Open Hole, Other	
WELL GROUTED TO A DEPTH OF 10 FEET Type Grout (circle one): (Cement) Bentonite, or Mix	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET		IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE	

SCREEN DATA		
Diameter - Inches 2"	Length - Feet 10'	Slot Size - Inches .006
Screen Type PVC	Depth to Bottom - Feet 290'	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
mud	0	40
sand	40	70
mud	70	210
sand	210	240

FORMATIONS (Continued)	FROM	TO
RECEIVED		
APR 10 1995		
Dept. of Environmental Quality Office of Land & Water Resources		
IF MORE SPACE IS NEEDED USE BACK		

