

N2072

Hancock

N 2072

8-68

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

8-2 1968 Sutter Well Works Hancock
 date well completed firm name county well located

DR. LANDOWNER: RA Mouton

description of formations encountered

	from	to
<u>Clay</u>	<u>0</u>	<u>17</u>
<u>sand</u>	<u>17</u>	<u>23</u>
<u>Clay</u>	<u>23</u>	<u>78</u>
<u>sand</u>	<u>78</u>	<u>108</u>
<u>Clay</u>	<u>108</u>	<u>295</u>
<u>sand</u>	<u>295</u>	<u>367</u>

CHARITY Hospital

New Orleans La.
 (mailing address)

WELL LOCATION:

sec. 30 T. 9 N. R. 14 E.
1 miles S of Deakshon
 (distance) (direction) (nearest town)

WELL PURPOSE: home
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 2
- (2) total depth (feet) 367
- (3) static water level (feet) 2 below above top of ground.
- (4) casing galv. 357'
 (material) (depth)
2"
 (size) if telescope see back.
- (5) screen 10' 357'
 (length) (depth to top)
2" Stainless Steel
 (size) (material)
- (6) pump 1/2 10
 (HP) (yield gpm)
elec
 (type power)
- (7) electric log no
 (yes or no)

(organization running log)

SEP 12 1968

(8) how well bottom plugged B.P. Value

MISS. BD. OF WATER COMM.

DRILLERS REMARKS: