

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

COUNTY WELL LOCATED
HARRISON

WELL NUMBER CODED
B 2077

DATE WELL COMPLETED
9-08-88

PERMIT NUMBER
0-239

NAME OF DRILLING FIRM
McGill Pump & Well

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
Lois Rivera

Rt. #3 Box 200

Muport, Ms.

WELL LOCATION: SEC TOWNSHIP RANGE
23 5 S 12 E

DISTANCE DIRECTION NEAREST TQWN
6 Miles West of Savelle

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
~~Submersible~~ Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
~~Electric~~ Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____

Pump Capacity (GPM) No. of Stages Setting Depth
25 10 80' FT.

PUMP TEST
Well yielded **18** GPM with
a drawdown of **10** ft.
after **1** hours of pumping

WELL DATA

Well Depth 500	Casing Diameter (In.) 4" x 2"	Casing Length (Ft.) 20
Type of Casing PVC	Hole Depth 500	Depth to Static Water Level 40

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
~~Natural Development~~ Open Hole, Other
(Describe) _____

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): **No Log Run**,
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 2	Length - Feet 20	Slot Size - Inches 6
Screen Type PVC	Depth to Bottom - Feet 480	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

RECEIVED

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM
mud	0	240		
mud + sand	240	260		
sand	260	300		
mud + sand	300	320		
mud	320	350		
mud + sand	350	400		
mud	400	460		
mud + sand	460	480		
sand	500			

NOV 30 1988

Department of Natural Resources
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK

