

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
HRSN

WELL NUMBER
F 2292

DATE WELL COMPLETED
1-1-96

PERMIT NUMBER
D-239

NAME OF DRILLING FIRM
McGill

NAME & MAILING ADDRESS OF LANDOWNER
Bill Garrett
#18 Serenity
Pass Cr. Ms.

WELL LOCATION SEC TOWNSHIP RANGE
24 7 N 13 E
S W

DISTANCE DIRECTION NEAREST TOWN
1 Miles **N** of **I10**

OTHER LANDMARK

WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, **Well** Flowing Well, Other (Describe) _____

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P _____

Pump Capacity (GPM) No. of Stages Setting Depth _____ FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

No Pump Surveys

WELL DATA

Well Depth 410	Casing Diameter (In.) 2	Casing Length (Ft.) 390
Type of Casing PVC	Hole Depth 410	Depth to Static Water Level 70

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, **No Log Run**, Neutron, Other (Describe) _____

Name of Organization Running Log

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped, **Natural Development**, Open Hole, Other _____

WELL GROUTED TO A DEPTH OF **10** FEET
Type Grout (circle one): Cement, Bentonite, or **Mix**

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches 2	Length - Feet 20	Slot Size - Inches 0000
Screen Type PVC	Depth to Bottom - Feet 410	

Driller's Remarks

Top of Lap Pipe or Reduction in Casing _____ FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
MUD	0	200
SAND	200	260
MUD	260	360
SAND	360	410

FORMATIONS (Continued)

FROM TO

RECEIVED

AUG 16 1996

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK

