

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL
QUALITY**

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED HRSN	
WELL NUMBER J 2293	CODED
DATE WELL COMPLETED 1-21-96	

PERMIT NUMBER 0-239
NAME OF DRILLING FIRM McGill

NAME & MAILING ADDRESS OF LANDOWNER Bill Garrette #29 Serenity Pass Cr., Ms.			
WELL LOCATION	SEC 24	TOWNSHIP 7 N S	RANGE 13 E W
DISTANCE 1 Miles	DIRECTION N	NEAREST TOWN of 310	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. 0			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____		
Pump Capacity (GPM)	No. of Stages	Setting Depth FT.
PUMP TEST NO Pump furnished Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 400	Casing Diameter (In.) 2	Casing Length (Ft.) 380
Type of Casing PVC	Hole Depth 400	Depth to Static Water Level 70

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, No Log Run , Other (Describe) _____	
Name of Organization Running Log	

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe) _____

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

WELL GROUTED TO A DEPTH OF **10** FEET
Type Grout (circle one): Cement, Bentonite, or **Mix**

Driller's Remarks	
Top of Lap Pipe or Reduction in Casing FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE	

SCREEN DATA		
Diameter - Inches 2	Length - Feet 20	Slot Size - Inches 0006
Screen Type PVC	Depth to Bottom - Feet 400	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Mud	0	200
Sand	200	260
Mud	260	360
SAND	360	400

FORMATIONS (Continued)	FROM	TO
RECEIVED		
AUG 16 1996		
Dept. of Environmental Quality Office of Land & Water Resources		
IF MORE SPACE IS NEEDED, USE BACK		

