

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Harrison

WELL NUMBER 2164 CODED

DATE WELL COMPLETED
2-8-93

PERMIT NUMBER 0-239

NAME OF DRILLING FIRM
McGill

Pump & Well

NAME & MAILING ADDRESS OF LANDOWNER
Pete

Allen Rd.

Dept.

WELL LOCATION SEC TOWNSHIP RANGE
70 N 110 E

DISTANCE DIRECTION NEAREST TOWN
Miles of

OTHER LANDMARK

WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 1

Pump Capacity (GPM) No. of Stages Setting Depth
15 2 FT.

PUMP TEST

Well yielded 10 GPM with
a drawdown of 10 ft.
after 24 hours of pumping

WELL DATA

Well Depth <u>210</u>	Casing Diameter (In.) <u>2</u>	Casing Length (Ft.) <u>200</u>
Type of Casing <u>Pvc</u>	Hole Depth <u>210</u>	Depth to Static Water Level

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches <u>2</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>6</u>
Screen Type <u>Pvc</u>	Depth to Bottom - Feet <u>210</u>	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Mud</u>	<u>0</u>	<u>180</u>
<u>Mud-sand</u>	<u>180</u>	<u>200</u>
<u>Sand</u>	<u>200</u>	<u>210</u>

RECEIVED

DEC 07 1993

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED USE BACK

