

Harrison
M225
7-67

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

7-14 1967 Sutter Well Works Harrison
date well completed firm name county well located

LANDOWNER: Collins Bldg Service
539 Caillenet
Biloxi, Miss.
(mailing address)

WELL LOCATION:
sec. 12 T. 7 S. R. 10 W.
3 miles N of Biloxi
(distance) (direction) (nearest town)

WELL PURPOSE: sub-division
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 4x6
- (2) total depth (feet) 278
- (3) static water level (feet) 6 ~~below~~ above top of ground.
- (4) casing Beh steel 218'
(material) (depth)
4x6" If telescope see back.
(size)
- (5) screen 60' 218'
(length) (depth to top)
4" Stainless Steel
(size) (material)
- (6) pump 10 150
(HP) (yield gpm)
elec
(type power)
- (7) electric log no
(yes or no)
(organization running log)
- (8) how well bottom plugged BP Valve

Description of formations encountered	from	to
Clay	0	15
sand	15	21
Clay	21	189
sand	189	204
Clay	204	418
sand	418	526
Clay	526	625
Sand - fine	625	685
sand	685	778

CODED



DRILLERS REMARKS:

If well telescopes please sketch and show depths.

GROUND LEVEL

105' of 6" BLK.

613' of 4" helix

60' of 4" stainless steel strainer



	X		

SECTION 12

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen, show locations of each on sketch.