

Harrison
M 336
2-28-70

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201
WATER WELL DRILLERS LOG

CODED

2-28 1970 Sutter Well Works Harrison
date well completed firm name county well located

LANDOWNER: DR. J. T. TAYLOR

Taylor Road

Handsboro, Miss.
(mailing address)

WELL LOCATION:

sec. 19 T 7 S R 10 W
1 miles N of Handsboro
(distance) (direction) (nearest town)

WELL PURPOSE: home
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 2 x 4"
- (2) total depth (feet) 758'
- (3) static water level (feet) 6' below top of ground ^{above} _{below}
- (4) casing galv. 738' (material) (depth)
2" x 4" (size) if telescope see back.
- (5) screen 20' 738' (length) (depth to top)
2" (size) Stainless steel (material)
- (6) pump 1 (HP) 20 (yield gpm)
elec (type power)
- (7) electric log no (yes or no)
- (organization running log)
- (8) how well bottom plugged BP Valve

description of formations encountered

from to

Clay	0	18
Sand	18	30
Clay	30	230
Sand	230	269
Clay	269	662
Sand	662	758

DRILLERS REMARKS:

MISS. BD. OF
WATER COMM.

FEB 24 1970

If well telescopes please sketch and show depths.

GROUND LEVEL

147' of 4" galv.

591' of 2" galv.

20' of 2" screen

		X	

SECTION 19

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen, show locations of each on sketch.