

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Harrison	
WELL NUMBER M 2516	CODED
DATE WELL COMPLETED 8-8-96	

PERMIT NUMBER 0-239
NAME OF DRILLING FIRM McGill

NAME & MAILING ADDRESS OF LANDOWNER Andy Gutierrez			
Bearden Pump & Well			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	28	7	N 9 E
		S	9 W
DISTANCE	DIRECTION	NEAREST TOWN	
_____ Miles	_____ of	_____	
OTHER LANDMARK			
WELL PURPOSE: <u>Home</u> , Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA	
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____	
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____	
Pump Capacity (GPM)	No. of Stages
	Setting Depth
	FT.
PUMP TEST	
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping	

WELL DATA		
Well Depth 200	Casing Diameter (In.) 2	Casing Length (Ft.) 190
Type of Casing PVC	Hole Depth 200	Depth to Static Water Level
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, <u>Natural Development</u> , Open Hole, Other (Describe) _____		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log	

WELL GROUTED TO A DEPTH OF 10 FEET Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET	IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

SCREEN DATA		
Diameter - Inches 2	Length - Feet 10	Slot Size - Inches 0006
Screen Type PVC	Depth to Bottom - Feet 200	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
SAND	0	20
Mud	20	100
Sand	100	110
Mud	110	180
Sand	180	200

FORMATIONS (Continued)	
FROM	TO
RECEIVED	
AUG 06 1999	
Dept. of Environmental Quality Office of Land & Water Resources	
IF MORE SPACE IS NEEDED, USE BACK	

