
Stata	Voll Doport		
		For Office Use Only:	
County: Harrison Mississippi Departm	Mississippi Department of Environmental Quality		
Permit # Office of Land	Office of Land and Water Resources		
	. Box 10631 MS 39289-0631	Well #: <u>0 - 385</u> L. S. Elevation:	
Date drilling completed: $8 - 11 - 06$ (60)	1)961-5210		
(601)354-6938 (fax)		E-log #:	
State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.			
Well Owner Information		Location	
Owner Name_ChrisSchmidt	Latitude: <u>30.21.055</u>	5" Longitude: 089. 12 . 013."	
Mailing Address: 4426 Menge Ave .	Method of Lat/Long (circle or		
A	USGS quad, (Hand-held	GPS, Survey-grade GPS	
HISSCHRISTIAN, MS City State Zip Code	<u>SE 14 SW</u> 14 Sec 8	Twn T85 Rng R12W	
Telephone No. (2018) 452 - 0653	Distance Direction	Nearest Town of PASS ChRISTIAN	
Well Data			
Purpose of Well (circle one Home Industrial Public Supply Irrigation Fish Culture Other:			
Date well drilling started: 8-9-06 Date well drilling completed: 8-11-06			
If flowing, method of flow regulation: Valve NA Other (describe)			
Static Water Level: 40feet above or below (circle one) land surface Date measured: 8-11-06			
Method of Measurement (circle one) steel tape electric tape air line other:			
Hole depth: $(000')$ Well depth: $(000')$ Well grouted to a depth of 10 feet			
Type of grout (circle one): Cement Bentonite Mix			
Casing length $\frac{380'X2''}{100}$ feet Casing diameter: $\frac{4''X2''}{100}$ inches Type of casing: $\frac{9VC}{100}$			
Screen length: $\underline{\partial C}$ feet Screen diameter: $\underline{\partial}$ inches Type of screen: $\underline{\rho VC}$			
Screen slot size: 1000 inches Setting depth: From 580 feet to 600 feet			
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development			
Other (describe):			
Top of lap pipe or reduction in casing: <u>NIA</u> feet. If telescoped or more than one screen, describe on back of page			
Logs run (circle all applicable): No log run Electric Gamma Ra	ay Density Sonic Neutron	Other:	
Name of organization running log(s): N/A I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi			
Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.			
Jack Ridgdell 0-472			
Print Name of Water Well Contractor and License No.	Signature of	Water Well Contractor	
		AUG 2 9 2006	

, **I**.,


BY: OLWR

\$-385

If well telescopes please sketch below and show depths.



If more than one screen, show location of each on sketch



ach Rentidue Signature of Water Well Contractor

AUG 2 9 2006 BY: OLWR

STATE WELL REPORT			
County: <u>HUM/ISON</u> Permit #: Driller: <u>COAST WA HUWEIISRV</u> . Dut completed: 8-11-06	Part 2 For Office Use Only: s Completion Report Aquifer: and Water Resources MS 39289-0631 box 10631 Well #: <u>\$2-3855</u> box 10631 Elevation:		
This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the			
installation of pump. Well Owner Information Owner Name: Chris Schmidt Mailing Address: 4426 Menge Ave. <u>Plss Christian, Ms 39571</u> City State Zip Code Telephone No. 628452 - 0653	Well Location Latitude: $20^{\circ}21'055''$ Longitude: $089''12'013''$ O3 O1 Method of Lat/Long (circle one): Conventional Survey, USGS quad, Hand-held GPS, Survey-grade GPS SE 1/4 SW 1/4 Sec S Twn T85 Rng R 12 W Distance Direction Nearest Town Miles NO MHof Ass		
Pump Type Circle one	Power Type Circle one		
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas		
Bucket Piston Turbine	Electric Motor Hand Tractor PTO		
Centrifugal Rotary Flowing Well	Windmill Other (specify):		
Other (specify): Date Pump Installed: 8-16-06 Rated Pump Capacity: /O Gallons Per Minute	Horse Power Rating of Motor: <u>1 HP</u> Setting Depth: <u>80FT. Droppipe</u> feet Number of Stages: <u>11</u>		
Pump Test Data Date Well Tested: $8 - 16 - 06$ Static Water Level (A): 40 Feet Below Land Surface Pumping Water Level (B): $1/A$ Feet Below Land Surface Drawdown [(B) - (A)]: 40 Feet Below Land Surface Test Pumping Rate: 10 Gallons Per Minute Duration of Pump Test (minimum 4 hours): 4 hours	Method of Measuring Water Level Circle one Air Line Electric Measuring Line Steel Tape Other (specify):		
I HEREBY CERTIFY that the above statements are true to the best of my knowledge. <u>John Elkins 0-716P</u> Print Name of Pump Installer and License No. (if applicable) <u>Signature of Pump Installer</u> <u>AU5-2-9-2005</u>			

· · ·

AUG 2 9 2005 BY: OLW H